



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Brevard

License Number: 1501583

DAYS INN TITUSVILLE KENNEDY SPACE CENTER

License Type: Lodging

3755 CHENEY HWY , TITUSVILLE 32780

Insp Date: 03/06/2026

Inspection Number: 1244356

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1504611

BLUFF WALK APARTMENTS

License Type: Lodging

1801 RIVERVIEW DR , MELBOURNE 32901

Insp Date: 03/06/2026

Inspection Number: 1635260

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher by apartment 101

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1612422

LAQUINTA INN & SUITES

License Type: Lodging

351 W HILLSBORO BLVD , DEERFIELD BEACH 33441

Insp Date: 03/11/2026

Inspection Number: 1246411

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.1. Fire extinguisher between rooms 135-137, 227-229 in the secondary B building.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1620843

**RESIDENCE INN BY MARRIOTT FORT LAUDERDALE
SW/MIRAMAR**

License Type: Lodging

14700 SW 29 ST , MIRAMAR 33027

Insp Date: 03/11/2026

Inspection Number: 1187174

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1605075

COURTYARD BY MARRIOTT

License Type: Lodging

5001 N FEDERAL HWY , FORT LAUDERDALE 33308

Insp Date: 03/11/2026

Inspection Number: 1244278

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1620931

HOTOLOS FORT LAUDERDALE

License Type: Lodging

3001 N FEDERAL HWY , FORT LAUDERDALE 33306

Insp Date: 03/10/2026

Inspection Number: 1245157

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. Expired 1-22-2026. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2000961

HAMPTON INN & SUITES JACKSONVILLE ORANGE PARK

License Type: Lodging

141 PARK AVE , ORANGE PARK 32073

Insp Date: 03/11/2026

Inspection Number: 1187243

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher is in the recharge zone at room #221.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2305901

SOCORRO'S INVESTMENT.

License Type: Lodging

14501 SW 117 AVE , MIAMI 33186

Insp Date: 03/09/2026

Inspection Number: 1643674

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher on second floor of building D(11520) pressure gauge indicates the extinguisher is in need of recharge.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2324370

STRATFORD APARTMENTS

License Type: Lodging

9051 SW 122 AVE , MIAMI 33186

Insp Date: 03/13/2026

Inspection Number: 1644762

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher across from unit 106 in building 2 (9011) in need of charge.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2301965

CARRENO APTS

License Type: Lodging

852 SW 1 ST , MIAMI 01231

Insp Date: 03/10/2026

Inspection Number: 1629832

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at FE near mailboxes.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2315878

DBA SUMMER GROVE

License Type: Lodging

10307 CORAL WAY , MIAMI 33165

Insp Date: 03/06/2026

Inspection Number: 1640269

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

02-04-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. Observed propane tank stored on 2nd floor of building of building 10307.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330629

MAX'S LANDING

License Type: Lodging

8905 SW 169 CT , MIAMI 33196

Insp Date: 03/13/2026

Inspection Number: 1642309

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2317292

HOLIDAY INN

License Type: Lodging

7707 NW 103 ST , HIALEAH GARDENS 33016

Insp Date: 03/13/2026

Inspection Number: 1187614

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 03/14/2026

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2329546

DOLCE BY WYNDHAM

License Type: Lodging

1745 JAMES AVE , MIAMI BEACH 33139

Insp Date: 03/06/2026

Inspection Number: 1189032

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2331456

FLOW HOUSE LEASING LLC

License Type: Lodging

697 N MIAMI AVE , MIAMI 33136

Insp Date: 03/13/2026

Inspection Number: 1646431

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2306412

SAN SOUCI APTS LLC

License Type: Lodging

11607 CANAL DR , NORTH MIAMI 33181

Insp Date: 03/12/2026

Inspection Number: 1642406

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Missing extinguisher in the box by unit 3.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328954

SUNSHINE INN OF MIAMI

License Type: Lodging

4839 W FLAGLER ST , MIAMI 33134

Insp Date: 03/09/2026

Inspection Number: 1244225

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2324062

GROD GROUP INVESTMENTS,LLC

License Type: Lodging

553 SW 5 ST , MIAMI 33130

Insp Date: 03/11/2026

Inspection Number: 1643893

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at second floor next to unit 4.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328235

HOMEWOOD SUITES MIAMI AIRPORT BLUE LAGOON

License Type: Lodging

5500 WATERFORD DISTRICT DR , MIAMI 33126

Insp Date: 03/13/2026

Inspection Number: 1186430

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2329214

GRAYSON MIAMI

License Type: Lodging

1100 BISCAYNE BLVD , MIAMI 33132

Insp Date: 03/11/2026

Inspection Number: 1187422

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2311562

PRESTIGE CORNERSTONE

License Type: Lodging

12300 NE 4 AVE , NORTH MIAMI 33161

Insp Date: 03/09/2026

Inspection Number: 1638083

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2310405

MARIO ROMERO 180

License Type: Lodging

180 E 9 ST , HIALEAH 33010

Insp Date: 03/12/2026

Inspection Number: 1640474

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

06-03-4

Marked exit is inaccessible. For reporting purposes only. Observed furniture plants on hallway, second floor first floor ,

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328969

CADILLAC HOTEL & BEACH CLUB, AUTOGRAPH COLLECTION

License Type: Lodging

3925 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 03/11/2026

Inspection Number: 1188261

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed expired boiler certificate since 3/2/2025 (FL 134078, 134079, 134080 , 134081, 130305, 130306, 130304). **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 03/14/2026

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2328235

HOMEWOOD SUITES MIAMI AIRPORT BLUE LAGOON

License Type: Lodging

5500 WATERFORD DISTRICT DR , MIAMI 33126

Insp Date: 03/13/2026

Inspection Number: 1186430

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed FL 136919, Expired 02/28/2025, FL 134832 Expired 02/28/2025.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329090

MARENAS RESORT

License Type: Lodging

18683 COLLINS AVE , SUNNY ISLES BEACH 33160

Insp Date: 03/09/2026

Inspection Number: 1186394

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Manager provided certificates from City of Sunny Isles with boilers expiring on 10/16/26. Manager advised that inspection was done and she is awaiting boiler certificates from the State Fire Marshal.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2329221

SOHO HOUSE

License Type: Lodging

4385 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 03/10/2026

Inspection Number: 1189056

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

03-04-4	- From initial inspection : Fire sprinkler head obstructed/covered/ inadequate installation. For reporting purposes only. Observed sprinkler inside Ken shower area (spa) not properly installed. - From follow-up inspection 2026-03-10: As per chief engineer, sprinkles will be replaced this week.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 2329221

SOHO HOUSE

License Type: Lodging

4385 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 03/10/2026

Inspection Number: 1189254

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

03-04-4	- From initial inspection : Fire sprinkler head obstructed/covered. For reporting purposes only. Observed sprinkler inside menshower area (spa) not properly installed. **Repeat Violation** - From follow-up inspection 2026-03-10: As per chief engineer, they will replace the sprinklers this week. **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 2329221

SOHO HOUSE

License Type: Lodging

4385 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 03/10/2026

Inspection Number: 1189254

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed at the Panel located by the front desk. - From follow-up inspection 2026-03-10: Observed illuminated trouble light at the front panel by the front desk. **Time Extended**	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2329221

SOHO HOUSE

License Type: Lodging

4385 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 03/10/2026

Inspection Number: 1189056

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2026-03-10: Observed no boiler certificates. Also observed maintenance employees resetting the boilers constantly.	Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 2329221

SOHO HOUSE

License Type: Lodging

4385 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 03/10/2026

Inspection Number: 1189254

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2026-03-10: **Time Extended**	Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2325104

APARTMENTS OF SWALLOW DR

License Type: Lodging

403 SWALLOW DR , MIAMI SPGS 64493

Insp Date: 03/13/2026

Inspection Number: 1636843

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed fire extinguisher in between units 205 and 204 in the overcharge zone.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 2301430

COSSIO APARTMENTS

License Type: Lodging

1870 SW 3 AVE , MIAMI 91406

Insp Date: 03/06/2026

Inspection Number: 1627848

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at FE next to unit 5.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2330065

LOS ANGELES 2016 LLC

License Type: Lodging

1529 NW 1 ST , MIAMI 33125

Insp Date: 03/13/2026

Inspection Number: 1626936

Insp Type: Routine - Lodging

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330065

LOS ANGELES 2016 LLC

License Type: Lodging

1529 NW 1 ST , MIAMI 33125

Insp Date: 03/13/2026

Inspection Number: 1626936

Insp Type: Routine - Lodging

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only. Observed alarm silenced light on at the alarm panel.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Duval

License Number: 2613220

MEETINGHOUSE AT COLLINS COVE

License Type: Lodging

5400 COLLINS LAKE DR , JACKSONVILLE 32244

Insp Date: 03/06/2026

Inspection Number: 1643578

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Portable fire extinguisher next to elevator near unit #4102 in red recharge zone.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 2609817

QUALITY INN & SUITES

License Type: Lodging

8333 DIX ELLIS TRL , JACKSONVILLE 32256

Insp Date: 03/10/2026

Inspection Number: 1186806

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher by boiler room in recharge zone.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 2702303

QUALITY INN

License Type: Lodging

6919 PENSACOLA BLVD , PENSACOLA 32505

Insp Date: 03/11/2026

Inspection Number: 1246224

Insp Type: Complaint Partial

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Outlet behind bed in room 140 is damaged and missing a face plate.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Hendry

License Number: 3600473

HARLEM GARDENS APARTMENTS

License Type: Lodging

700 HARLEM TENANTS CR #712, CLEWISTON 33440

Insp Date: 03/06/2026

Inspection Number: 1625357

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only at unit 809. Operator brought to location. ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3600462

HOLIDAY INN EXPRESS HOTEL & SUITES

License Type: Lodging

1024 W SUGARLAND HWY , CLEWISTON 33440

Insp Date: 03/06/2026

Inspection Number: 1187672

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FL136106 7/12/23. Operator has correspondence for inspection but inspector has not been by to reinspect or recertify. ****Corrective Action Taken** **Repeat Violation****

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Hillsborough

License Number: 3905670

EMBASSY SUITES BY HILTON TAMPA AIRPORT WESTSHORE

License Type: Lodging

555 N WESTSHORE BLVD , TAMPA 33609

Insp Date: 03/12/2026

Inspection Number: 1187394

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4605709

COVE AT 2950

License Type: Lodging

2950 ROYAL PALM AVE , FORT MYERS 33901

Insp Date: 03/11/2026

Inspection Number: 1632187

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher outside Unit 104 pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Lee

License Number: 4604542

WALTERS RENTAL

License Type: Lodging

739- 751 VERONICA S SHOEMAKER BLVD , FORT MYERS 33916

Insp Date: 03/12/2026

Inspection Number: 1637729

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher not accessible near unit 745. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4605744

ROYAL PALM APARTMENTS

License Type: Lodging

2771 ROYAL PALM AVE , FORT MYERS 33901

Insp Date: 03/06/2026

Inspection Number: 1626222

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher outside of Unit 301 pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Lee

License Number: 4602172

CENTURY OAKS

License Type: Lodging

120 TRAFALGAR PWKY , CAPE CORAL 33991

Insp Date: 03/06/2026

Inspection Number: 1631992

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Observed cable cover panel missing front building on the left facing Trafalgar Road.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 4800237

WILLISTON ARMS PHASE II

License Type: Lodging

75 WILLISTON ARMS DR , WILLISTON 32696

Insp Date: 03/06/2026

Inspection Number: 1633889

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Fire extinguisher missing from hanger on back of unit #54.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Report Date: 03/14/2026

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Martin

License Number: 5300993

PIRATE'S COVE RESORT & MARINA

License Type: Lodging

4307 SE BAYVIEW ST , STUART 34997

Insp Date: 03/09/2026

Inspection Number: 1189432

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5403157

OLD TOWN KEY WEST DEV LTD

License Type: Lodging

717 SAMARITIN LN , KEY WEST 33040

Insp Date: 03/11/2026

Inspection Number: 1628202

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed outside of unit 4.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Orange

License Number: 5811136

ALFOND INN

License Type: Lodging

300 E NEW ENGLAND AVE , WINTER PARK 32789

Insp Date: 03/10/2026

Inspection Number: 1188361

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.Boiler jurisdiction 122081, 122082 exp. 10/11/2024 boiler room at 5th floor Rooftop	Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 5809236

HOMEWOOD SUITES BY HILTON ORLANDO INTERNATIONAL DRIVE

License Type: Lodging

8745 INTERNATIONAL DR , ORLANDO 32819

Insp Date: 03/12/2026

Inspection Number: 1185468

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only./one boiler certificate expired. FL 093756/located on 6th floor.	Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Palm Beach

License Number: 6013634

VERONA AT BOYNTON BEACH APARTMENTS

License Type: Lodging

1575 SW 8 ST , BOYNTON BEACH 33426

Insp Date: 03/06/2026

Inspection Number: 1643315

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge invisible at building 3 south side . For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215784

HYATT REGENCY CLEARWATER RESORT AND SPA

License Type: Lodging

301 S GULFVIEW BLVD , CLEARWATER BEACH 33767

Insp Date: 03/06/2026

Inspection Number: 1186823

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215784

HYATT REGENCY CLEARWATER RESORT AND SPA

License Type: Lodging

301 S GULFVIEW BLVD , CLEARWATER BEACH 33767

Insp Date: 03/06/2026

Inspection Number: 1186823

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FI123659, FI123660 expired 1/25/2026

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Pinellas

License Number: 6206527

MYSTIC BAY APARTMENTS

License Type: Lodging

600 STARKEY RD , LARGO 33771

Insp Date: 03/11/2026

Inspection Number: 1646567

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to unit 1508, first floor building 15.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215860

CLUB WYNDHAM CLEARWATER BEACH

License Type: Lodging

110 CORONADO DR , CLEARWATER 33767

Insp Date: 03/13/2026

Inspection Number: 1187459

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Seminole

License Number: 6903650

EXTENDED STAY AMERICA #9634

License Type: Lodging

302 NORTHLAKE BLVD , ALTAMONTE SPRINGS 32701

Insp Date: 03/12/2026

Inspection Number: 1189381

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2026-03-12: **Time Extended**	Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 6900381

OPAL HOTEL & SUITES

License Type: Lodging

230 W SR 436 , ALTAMONTE SPRINGS 32714

Insp Date: 03/12/2026

Inspection Number: 1242001

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.-063625. - From follow-up inspection 2026-03-12: **Time Extended**	Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

St. Lucie

License Number: 6602527

TOWNSHIP SUITES PORT ST LUCIE

License Type: Lodging

10460 SW VILLAGE PKWY , PORT ST LUCIE 34987

Insp Date: 03/06/2026

Inspection Number: 1187460

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Screen reads: Ground Fault Loop 1. Per Housekeeping Manager, fire dept has been out to fix 3 times that she knows about. **Corrective Action Taken**	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 6602528

LIVE OAK PRESERVATIONS LTD

License Type: Lodging

919 25TH ST , FORT PIERCE 34947

Insp Date: 03/06/2026

Inspection Number: 1646535

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Near 106 building 2	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 6602284

MAINSTAY SUITES

License Type: Lodging

8501 CHAMPIONS WAY , PORT ST LUCIE 34986

Insp Date: 03/06/2026

Inspection Number: 1189400

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

01-02-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to guest laundry. - From follow-up inspection 2026-03-06: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

St. Lucie

License Number: 6602284

MAINSTAY SUITES

License Type: Lodging

8501 CHAMPIONS WAY , PORT ST LUCIE 34986

Insp Date: 03/06/2026

Inspection Number: 1189400

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble = 1 on panel. - From follow-up inspection 2026-03-06: ****Time Extended****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7000413

EXTENDED STAY AMERICA SELECT SUITES WILDWOOD-THE VILLAGES

License Type: Lodging

4867 INSPIRATION WAY , WILDWOOD 34785

Insp Date: 03/12/2026

Inspection Number: 1186540

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.Room 114

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400503

BAYMONT BY WYNDHAM

License Type: Lodging

2725 W INTERNATIONAL SPWY BLVD , DAYTONA BEACH 32114

Insp Date: 03/06/2026

Inspection Number: 1246385

Insp Type: Complaint Partial

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

06-02-4

Door marked as an exit is blocked. For reporting purposes only.-marked exit in lobby locked ,breakfast area

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7400051

ECONO LODGE/SUBURBAN STUDIOS DAYTONA BEACH SPEEDWAY

License Type: Lodging

2904 W INTL SPEEDWAY BLVD , DAYTONA BEACH 32124

Insp Date: 03/13/2026

Inspection Number: 1242486

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.-at stairs by room 189,290 ,132 and 231, -at stairs by exit of old breakfast area.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401352

DAYTONA INN

License Type: Lodging

1305 S RIDGEWOOD AVE , DAYTONA BEACH 32114

Insp Date: 03/11/2026

Inspection Number: 1244398

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

02-07-4

Flammable chemicals stored near a source of ignition. For reporting purposes only.-box stored next to water heater-lawn mower near water heater

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7406502

HAMPTON INN & SUITES

License Type: Lodging

20 SUMMIT OAK PL , DELAND 32720

Insp Date: 03/06/2026

Inspection Number: 1187848

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 7400945

COMFORT INN AND SUITES OCEANFRONT

License Type: Lodging

295 S. ATLANTIC AVE , ORMOND BEACH 32176

Insp Date: 03/12/2026

Inspection Number: 1244626

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7400051

**ECONO LODGE/SUBURBAN STUDIOS DAYTONA BEACH
SPEEDWAY**

License Type: Lodging

2904 W INTL SPEEDWAY BLVD , DAYTONA BEACH 32124

Insp Date: 03/13/2026

Inspection Number: 1242486

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

06-01-4

Path to door marked as an exit is blocked. For reporting purposes only.-table and chairs stored in front of of marked exit in form breakfast area.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400503

BAYMONT BY WYNDHAM

License Type: Lodging

2725 W INTERNATIONAL SPWY BLVD , DAYTONA BEACH 32114

Insp Date: 03/10/2026

Inspection Number: 1246385

Insp Type: Complaint Partial

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

06-02-4

- From initial inspection : Door marked as an exit is blocked. For reporting purposes only.-marked exit in lobby locked ,breakfast area - From follow-up inspection 2026-03-10:

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 03/14/2026

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7400503

BAYMONT BY WYNDHAM

License Type: Lodging

2725 W INTERNATIONAL SPWY BLVD , DAYTONA BEACH 32114

Insp Date: 03/11/2026

Inspection Number: 1246385

Insp Type: Complaint Partial

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

06-02-4

- From initial inspection : Door marked as an exit is blocked. For reporting purposes only.-marked exit in lobby locked ,breakfast area - From follow-up inspection 2026-03-10: - From follow-up inspection 2026-03-11:

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.