



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Alachua

License Number: 1103169

SAR PROPERTY MANAGEMENT

License Type: Lodging

412 SW 69 ST , GAINESVILLE 32607

Insp Date: 05/07/2026

Inspection Number: 1640831

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed : fire extinguisher box on the wall, no fire extinguisher. **Repeat Violation**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 1102991

ALIGHT GAINESVILLE

License Type: Lodging

725 NW 13 ST , GAINESVILLE 32601

Insp Date: 05/05/2026

Inspection Number: 1625376

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

07-01-4	Damaged electrical wire(s). For reporting purposes only. Fire alarm hanging by wires in front of unit 1112. **Repeat Violation**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Alachua

License Number: 1100353

CAMPUS INN GAINESVILLE

License Type: Lodging

2820 NW 13 ST , GAINESVILLE 92832

Insp Date: 05/05/2026

Inspection Number: 1246609

Insp Type: Complaint Full

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Half of smoke alarm missing in guest room 107	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 1500349

SURF STUDIO APTS M C

License Type: Lodging

1801 S ATLANTIC AVE , COCOA BCH 12343

Insp Date: 05/05/2026

Inspection Number: 1245748

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Between south side buildings **Repeat Violation**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Brevard

License Number: 1505711

PALMETTO RIDGE ESTATES

License Type: Lodging

1202 PRAIRIE LANE , TITUSVILLE 32780

Insp Date: 05/06/2026

Inspection Number: 1642605

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By building 1241 apartment 13108

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1500580

524 APARTMENT LLC

License Type: Lodging

524 S ATLANTIC AVE , COCOA BEACH 32931

Insp Date: 05/05/2026

Inspection Number: 1629290

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Brevard

License Number: 1505782

ATLANTIC VIEW APARTMENTS

License Type: Lodging

310 MCKINLEY AVE UNIT A , COCOA BEACH 32931

Insp Date: 05/08/2026

Inspection Number: 1642825

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

02-04-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. Propane tanks in housekeeping storage room ****Corrected On-Site****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1502495

MONROE ON MONTEREY

License Type: Lodging

1635 MONTEREY DR NE , PALM BAY 32905

Insp Date: 05/01/2026

Inspection Number: 1641990

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Fire panel in trouble status, operator stated they are in process of correcting with servicing company. ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Brevard

License Number: 1505917

POINTE AT PALM BAY

License Type: Lodging

205 VALOR DRIVE SE , PALM BAY 32907

Insp Date: 05/05/2026

Inspection Number: 1638371

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Fire panel in trouble status.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1502495

MONROE ON MONTEREY

License Type: Lodging

1635 MONTEREY DR NE , PALM BAY 32905

Insp Date: 05/01/2026

Inspection Number: 1641990

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Apartment C310 smoke detector not operable.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Brevard

License Number: 1500349

SURF STUDIO APTS M C

License Type: Lodging

1801 S ATLANTIC AVE , COCOA BCH 12343

Insp Date: 05/05/2026

Inspection Number: 1245748

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. In unit 7. Outlet hanging out of wall exposing wires	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 1621201

ECLIPSE WEST APARTMENTS

License Type: Lodging

307 NW 1 AVE , FORT LAUDERDALE 33301

Insp Date: 05/04/2026

Inspection Number: 1644164

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. 12th floor by staircase 210th floor by staircase 18th floor by staircase 17th floor by staircase 1	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 1621442

PEARL

License Type: Lodging

3880 W BROWARD BLVD , PLANTATION 33312

Insp Date: 05/05/2026

Inspection Number: 1637289

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. 1. Building 4 (3840)	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1607235

2209 NE 2ND ST LLC

License Type: Lodging

2209 NE 2 ST , POMPANO BEACH 33062

Insp Date: 05/01/2026

Inspection Number: 1638275

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Fire extinguisher in Overcharge Zone, next to room 8 on second floor upstairs.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621585

ZANBNB LLC

License Type: Lodging

421 SUNSET DR , POMPANO BEACH 33062

Insp Date: 05/05/2026

Inspection Number: 1627564

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Fire extinguisher located near to laundry room in Overcharge Zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1621703

SURF AND SAND

License Type: Lodging

601 N OCEAN BLVD , POMPAN0 BEACH 33062

Insp Date: 05/01/2026

Inspection Number: 1635112

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Fire extinguisher located next to room 14, in Recharge Zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621877

WAG PLUS ENTERPRISES LLC

License Type: Lodging

812 NE 17 TERR , FORT LAUDERDALE 33304

Insp Date: 05/07/2026

Inspection Number: 1630176

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Between unit 3 and 4

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1620382

MARINA GARCEV APARTMENTS

License Type: Lodging

1095 SE 22 AVE , POMPAÑO BEACH 33062

Insp Date: 05/05/2026

Inspection Number: 1630689

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher located ext to room # 1 in Recharge Zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621749

EON SQUARED

License Type: Lodging

444 NE 7TH STREET , FORT LAUDERDALE 33304

Insp Date: 05/01/2026

Inspection Number: 1643861

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Unit 809 Unit 617 Unit 428 Unit 228

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1617550

INBAR 2

License Type: Lodging

801 SW 15 AVE , FORT LAUDERDALE 33312

Insp Date: 05/07/2026

Inspection Number: 1632909

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.1. Between unit 33 and 34

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620382

MARINA GARCEV APARTMENTS

License Type: Lodging

1095 SE 22 AVE , POMPANO BEACH 33062

Insp Date: 05/05/2026

Inspection Number: 1630689

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.Fire extinguisher missing from storage box, near to room # 5.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1612092

CIELO POINT

License Type: Lodging

6701 W OAKLAND PARK BLVD , FORT LAUDERDALE 33313

Insp Date: 05/01/2026

Inspection Number: 1642621

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.Observed fire extinguisher missing in front of unit 106 building 6850.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1617550

INBAR 2

License Type: Lodging

801 SW 15 AVE , FORT LAUDERDALE 33312

Insp Date: 05/07/2026

Inspection Number: 1632909

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.1. By unit 40

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1620073

COURT AT PALM AIRE

License Type: Lodging

2701 N COURSE DR , POMPANO BEACH 33069

Insp Date: 05/08/2026

Inspection Number: 1625122

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1622090

ACS 4317 LLC

License Type: Lodging

4317 NE 21 AVE , FORT LAUDERDALE 33308

Insp Date: 05/04/2026

Inspection Number: 1638148

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. Front of Apt 4 (East side) exposed wires in junction box. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Broward

License Number: 1608463

COLINS APARTMENTS

License Type: Lodging

396 NW 40 CT , OAKLAND PARK 95188

Insp Date: 05/08/2026

Inspection Number: 1626446

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed next to unit 107	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 1900894

LAKE ROUSSEAU APARTMENTS

License Type: Lodging

10816 N KOMENT PT , CRYSTAL RIVER 34428

Insp Date: 05/07/2026

Inspection Number: 1246261

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.The housekeeper provided a Gentex hearing impaired smoke detector powered by a 9v battery. When placed into test mode, the alarm sounded but the light did not flash. **Warning**	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 2102775

TROPICAL APARTMENTS

License Type: Lodging

745 4 AVE S , NAPLES 34102

Insp Date: 05/01/2026

Inspection Number: 1629155

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.Fire extinguisher on the north side of building #1 next to the laundry machines in the red.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2328266

EXTENDED STAY AMERICA PREMIER STE (#1600)

License Type: Lodging

8655 NW 21 TERRACE , MIAMI 33122

Insp Date: 05/08/2026

Inspection Number: 1189688

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 2311837

NORTH MIAMI BEACH GARDEN INN & SUITE

License Type: Lodging

148 NW 167 ST , MIAMI 33169

Insp Date: 05/01/2026

Inspection Number: 1246446

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 2329831

FULLER ROSE LLC

License Type: Lodging

774 SW 47 AVE , MIAMI 33134

Insp Date: 05/04/2026

Inspection Number: 1646969

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Observed at apartment 4. **Warning**	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2311837

NORTH MIAMI BEACH GARDEN INN & SUITE

License Type: Lodging

148 NW 167 ST , MIAMI 33169

Insp Date: 05/01/2026

Inspection Number: 1246446

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

06-01-4

Path to door marked as an exit is blocked. For reporting purposes only. Observed discard mattress and unnecessary items blocked the exit door area.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329831

FULLER ROSE LLC

License Type: Lodging

774 SW 47 AVE , MIAMI 33134

Insp Date: 05/04/2026

Inspection Number: 1646969

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

11-03-4

Electric water heater in disrepair or electrical problem. As per tenant, the water heater located in apartment 4 underneath kitchen counter gets on even if all faucets from the apartment are off. It happens (water heater on) when the next door apartment # 3, tenant turns on the hot water at any apartment's faucet . For reporting purposes only. ****Warning****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2306925

C&N 2015 LLC

License Type: Lodging

825 NW 70 ST , MIAMI 33150

Insp Date: 05/07/2026

Inspection Number: 1629874

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.Observed extinguisher missing from box next to unit 2 due to apparent fire.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2305664

CLIFTON HOTEL

License Type: Lodging

1343 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 05/05/2026

Inspection Number: 1186689

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed fire panel trouble light on, stating Supervisory for room 144.
Repeat Violation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329465

LUXURI SUITES

License Type: Lodging

852 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 05/06/2026

Inspection Number: 1184923

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed Trouble/alarm light illuminated on the fire alarm control panel located at first floor.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2305664

CLIFTON HOTEL

License Type: Lodging

1343 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 05/05/2026

Inspection Number: 1186689

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Observed HI detector light not working properly, light not functioning.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2313073

736 NW 35TH STREET APTS

License Type: Lodging

736 NW 35 ST , MIAMI 73300

Insp Date: 05/08/2026

Inspection Number: 1629487

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

06-03-4

Marked exit is inaccessible. For reporting purposes only. Observed second floor stair way blocked by chair.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2305664

CLIFTON HOTEL

License Type: Lodging

1343 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 05/05/2026

Inspection Number: 1186689

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed no boiler certificate for boilers with capacity of 358.8 gallons and the other 200 gallons ****Repeat Violation****

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2331481

ONE SUNRISE

License Type: Lodging

427 NE 62 ST , MIAMI 33138

Insp Date: 05/08/2026

Inspection Number: 1646992

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed between units 4-5.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number:

1035 9TH 1044 PENN LLC

License Type: Lodging

1035 9 ST , MIAMI BEACH 33139

Insp Date: 05/06/2026

Inspection Number: 1646935

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed by unit 23.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: **1035 9TH 1044 PENN LLC**
License Type: Lodging 1035 9 ST , MIAMI BEACH 33139

Insp Date: 05/06/2026 Inspection Number: 1646935 Insp Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2331481 **ONE SUNRISE**
License Type: Lodging 427 NE 62 ST , MIAMI 33138

Insp Date: 05/08/2026 Inspection Number: 1646992 Insp Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2329498

TRU BY HILTON MIAMI WEST BRICKELL

License Type: Lodging

1931 SW 3 AVE , MIAMI 33129

Insp Date: 05/07/2026

Inspection Number: 1187437

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.Observed fire extinguisher across from room 317 indicating the extinguisher is over charged.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2331351

PLAZA GARDENIA APARTMENTS

License Type: Lodging

1330 W 29 ST , HIALEAH 33012

Insp Date: 05/07/2026

Inspection Number: 1630435

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.Observed between units 2-3 on building 1310.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2316403

CUTLER MANOR APARTMENTS

License Type: Lodging

10875 SW 216 ST , MIAMI 03103

Insp Date: 05/04/2026

Inspection Number: 1630516

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed on the right side of unit 412 near the stairs. Observed in the laundry room near unit 408. Observed across unit 224. Observed across unit 220. ****Repeat Violation****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329321

ALAMO AT MINE

License Type: Lodging

4121 INDIAN CREEK DR , MIAMI BEACH 33140

Insp Date: 05/04/2026

Inspection Number: 1188219

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observe at the main panel. ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2316403

CUTLER MANOR APARTMENTS

License Type: Lodging

10875 SW 216 ST , MIAMI 03103

Insp Date: 05/04/2026

Inspection Number: 1630516

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed at meter room across unit #116. ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2300993

LITTLE HAVANA - 2244 SW 9TH ST LLC

License Type: Lodging

2244 SW 9TH STREET , MIAMI 33135

Insp Date: 05/07/2026

Inspection Number: 1630796

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2329451

MADISON VIEW APARTMENTS

License Type: Lodging

642 NW 5 AVE STE# B-105 , MIAMI 33136

Insp Date: 05/04/2026

Inspection Number: 1634897

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. As per operator, awaiting service. **Corrective Action Taken**	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 2301957

BEACH PARK HOTEL

License Type: Lodging

600 OCEAN DR , MIAMI BEACH 96219

Insp Date: 05/05/2026

Inspection Number: 1188496

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificate last inspection date 4/5/2023.	Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2309933 **1035 9TH 1044 PENN LLC / JUNG MIAMI BEACH LLC**
License Type: Lodging 1035 9 ST , MIAMI BEACH 33139

Insp Date: 05/06/2026 Inspection Number: 1646823 Insp Type: Complaint Full Disposition: Call Back - Complied

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed by unit 23. - From follow-up inspection 2026-05-06: **Time Extended**	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329511 **STRAND OCEAN DRIVE SUITES**
License Type: Lodging 1052 OCEAN DRIVE , MIAMI BEACH 33139

Insp Date: 05/08/2026 Inspection Number: 1189330 Insp Type: Complaint Full Disposition: Call Back - Complied

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2026-05-08: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Time Extended**	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2307022 **NJZ ENTERPRISES INC**
License Type: Lodging 1237 NE 128 ST , NORTH MIAMI 33161

Insp Date: 05/08/2026 Inspection Number: 1646904 Insp Type: Complaint Full Disposition: Call Back - Complied

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-04-4	- From initial inspection : Fire alarm control panel has no power. For reporting purposes only. - From follow-up inspection 2026-05-08: On 5/08/2026 at the time of the callback inspection Fire alarm control panel has no power. For reporting purposes only. **Time Extended**	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2321990

QUALITY INN MIAMI AIRPORT

License Type: Lodging

3959 NW 79 AVE , MIAMI 33166

Insp Date: 05/04/2026

Inspection Number: 1188944

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2026-05-04: At time of callback inspection was unable to see Boiler Certification. **Time Extended**	Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 2321990

QUALITY INN MIAMI AIRPORT

License Type: Lodging

3959 NW 79 AVE , MIAMI 33166

Insp Date: 05/04/2026

Inspection Number: 1188944

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-04-4	- From initial inspection : Boiler certificate not posted in the boiler room. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2026-05-04: At time of callback inspection was unable to see Boiler Certification. **Time Extended**	Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2329302

ELEMENT MIAMI DORAL

License Type: Lodging

3285 NW 107 AVE , MIAMI 33172

Insp Date: 05/04/2026

Inspection Number: 1186810

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4	<p>- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed at main panel at fire alarm room. - From follow-up inspection 2026-05-04: At time of callback inspection observed Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed at main panel at fire alarm room. **Time Extended**</p>	<p>Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
---------	---	---

License Number: 2307517

TANGIBLE INVESTMENTS 3

License Type: Lodging

1575 PALM AVE , HIALEAH 33010

Insp Date: 05/07/2026

Inspection Number: 1629977

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

01-03-4	<p>Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.Observed between units it's 1-2.</p>	<p>Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
---------	---	---



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2315636

NEW ARENA SQUARE NO & SO LTD

License Type: Lodging

275 NW 10 ST , MIAMI 63403

Insp Date: 05/04/2026

Inspection Number: 1632761

Insp Type: Routine - Lodging

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. Did not observe for extinguisher on the outside of the units in building 275 of 268. As per operator, could be inside the units.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329714

VC 1553

License Type: Lodging

1553 SW 2 ST , MIAMI 33135

Insp Date: 05/06/2026

Inspection Number: 1639378

Insp Type: Routine - Lodging

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Duval

License Number: 2601594

PRESERVE AT ST NICHOLAS

License Type: Lodging

3952 ATLANTIC BLVD , JACKSONVILLE 32207

Insp Date: 05/01/2026

Inspection Number: 1636315

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In office

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2600079

OASIS AT SAN MARCO

License Type: Lodging

4800 ATLANTIC BLVD , JACKSONVILLE 32207

Insp Date: 05/05/2026

Inspection Number: 1634740

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Unit 209, employee brought one
Corrected On-Site

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913627

WESTIN TAMPA BAY

License Type: Lodging

7627 COURTNEY CAMPBELL CAUSEWAY , TAMPA 33607

Insp Date: 05/07/2026

Inspection Number: 1188242

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Hillsborough

License Number: 3913674 **EXTENDED STAY AMERICA 9506**
License Type: Lodging 8940 E SLIGH AVE , TAMPA 33610

Insp Date: 05/04/2026 Inspection Number: 1188500 Insp Type: Routine - Lodging Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 9/27/2024	Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913638 **ECONO LODGE**
License Type: Lodging 4139 E BUSCH BLVD , TAMPA 33617

Insp Date: 05/08/2026 Inspection Number: 1189621 Insp Type: Complaint Full Disposition: Call Back - Complied

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-05-4	- From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only.Observed missing fire detector in room 111. - From follow-up inspection 2026-05-08: Smoke detector still missing **Time Extended**	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Report Date: 05/09/2026

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Lee

License Number: 4605298

WESTWOOD APARTMENTS

License Type: Lodging

3739 METRO PKWY , FORT MYERS 33916

Insp Date: 05/07/2026

Inspection Number: 1643991

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-05-4	Portable fire extinguishers not accessible near apartments; 8207, 9107, 10103, 11107, 11102. For reporting purposes only.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 4601946

CORAL TERRACE

License Type: Lodging

1412 SE 8TH TERRACE , CAPE CORAL 33990

Insp Date: 05/07/2026

Inspection Number: 1635714

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed Fire Extinguisher between 13-14 Units missing glass protector.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Leon

License Number: 4701055

LA QUINTA INN TALLAHASSEE NORTH

License Type: Lodging

2905 N MONROE ST , TALLAHASSEE 32303

Insp Date: 05/05/2026

Inspection Number: 1246619

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. Smoke detectors in room do not work. For reporting purposes only.

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4703060

OYO MOTEL

License Type: Lodging

745 N MONROE ST , TALLAHASSEE 32303

Insp Date: 05/04/2026

Inspection Number: 1241987

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-03-4

Smoke detector/alarm in guest room/unit appear to be inoperable, room 212. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Leon

License Number: 4701498

RED ROOF INN

License Type: Lodging

2930 HOSPITALITY ST , TALLAHASSEE 32303

Insp Date: 05/06/2026

Inspection Number: 1242259

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5200252

DIXIE MOTEL

License Type: Lodging

1539 S PINE AVE , OCALA 34471

Insp Date: 05/06/2026

Inspection Number: 1246355

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Fire extinguisher missing from box in front of Establishment observed having rooms or apartments occupied with customers with an expired license room 11.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Marion

License Number: 5200184

FRIENDSHIP INN

License Type: Lodging

2829 E SILVER SPRINGS BLVD , OCALA 34470

Insp Date: 05/07/2026

Inspection Number: 1246246

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

04-05-4	No smoke detector provided in guest room/unit. For reporting purposes only.Room 4.	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 5200184

FRIENDSHIP INN

License Type: Lodging

2829 E SILVER SPRINGS BLVD , OCALA 34470

Insp Date: 05/07/2026

Inspection Number: 1246246

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

07-01-4	Exposed electrical wire(s). For reporting purposes only.Wires hanging from ceiling in front of rooms 3 and 16.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Monroe

License Number: 5400637

SEACOVE MOTEL & MARINA

License Type: Lodging

12685 OVERSEAS HWY , MARATHON 03536

Insp Date: 05/01/2026

Inspection Number: 1245276

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Unit 5	Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	---

License Number: 5500968

COURTYARD AMELIA ISLAND

License Type: Lodging

2700 ATLANTIC AVE STE 1 , AMELIA ISLAND 32034

Insp Date: 05/04/2026

Inspection Number: 1188532

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Displayed certificates expired 4-4-2025. Operator states boiler inspection was completed but wrong certificates were given. **Corrective Action Taken** **Repeat Violation**	Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Okaloosa

License Number: 5600026

FOUR POINTS SHERATON

License Type: Lodging

1325 MIRACLE STRIP PKWY , FORT WALTON BEACH 32548

Insp Date: 05/06/2026

Inspection Number: 1246116

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. ****Repeat Violation****

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811183

AVES @ TWELVE 100

License Type: Lodging

12100 STERLING UNIVERSITY LANE , ORLANDO 32826

Insp Date: 05/07/2026

Inspection Number: 1637691

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Palm Beach

License Number: 6001100

FLAGLER WPB OWNER LLC

License Type: Lodging

3907 S FLAGLER DR , WEST PALM BEACH 33405

Insp Date: 05/08/2026

Inspection Number: 1638176

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6000413

GHS.9ENTERPRISES LLC

License Type: Lodging

431 S M ST , LAKE WORTH 33460

Insp Date: 05/05/2026

Inspection Number: 1642723

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Gauge in overcharge zone at fire extinguisher on west side of property attached to staircase.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6000026

CHATEAU VILLAGE APARTMENTS

License Type: Lodging

240 ALEMEDA DR , PALM SPRINGS 11610

Insp Date: 05/07/2026

Inspection Number: 1635266

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Gauge on fire extinguisher inside of laundry room near unit 101 building 240 in recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Palm Beach

License Number: 6000662

CYPRESS APARTMENTS

License Type: Lodging

247 ALEMEDA DR , PALM SPRINGS 11617

Insp Date: 05/07/2026

Inspection Number: 1640411

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher gauge inside of laundry room building 246 in recharge zone. Fire extinguisher gauge across from unit 11 building 247 in recharge zone. Fire extinguisher gauge across from unit 8 building 247 in recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6014617

FITZGERALD CAMINO REAL

License Type: Lodging

103 W CAMINO REAL , BOCA RATON 33432

Insp Date: 05/01/2026

Inspection Number: 1642167

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble alarm on building 1

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Palm Beach

License Number: 6014190 **SW - LAKE WORTH LLC**
 License Type: Lodging 1001 S M ST , LAKE WORTH 33460

Insp Date: 05/05/2026 Inspection Number: 1631251 Insp Type: Routine - Lodging Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-06-4	Fire alarm control panel emitting an audible alarm. For reporting purposes only. Fire alarm control panel on first floor emitting a constant beeping noise. No trouble lights illuminated on panel.	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6014460 **MILHER ELNE**
 License Type: Lodging 302 SOUTH A ST , LAKE WORTH 33460

Insp Date: 05/06/2026 Inspection Number: 1624691 Insp Type: Routine - Lodging Disposition: Administrative complaint recommended

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Gauge in recharge zone on fire extinguisher in between unit 2 and 3.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Palm Beach

License Number: 6014460

MILHER ELNE

License Type: Lodging

302 SOUTH A ST , LAKE WORTH 33460

Insp Date: 05/06/2026

Inspection Number: 1624691

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Obstructed access to fire extinguisher stored in between unit 2 and 3 due to tenant storage of patio equipment, bicycles, and grill.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 6215772

INTOWN SUITES

License Type: Lodging

2833 ROOSEVELT BLVD , CLEARWATER 33760

Insp Date: 05/06/2026

Inspection Number: 1184394

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. On 3rd floor near room 313.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Pinellas

License Number: 6204347

BELLA ROSA

License Type: Lodging

411 S NIMBUS AVE , CLEARWATER 33765

Insp Date: 05/02/2026

Inspection Number: 1638750

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge between apartments 3 and 4. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6214991

GRE FL PROPERTY INVESTMENTS LLC

License Type: Lodging

300 SOUTH NIMBUS AVE , CLEARWATER 33765

Insp Date: 05/02/2026

Inspection Number: 1635230

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge in front of apartment 8. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Pinellas

License Number: 6215772

INTOWN SUITES

License Type: Lodging

2833 ROOSEVELT BLVD , CLEARWATER 33760

Insp Date: 05/06/2026

Inspection Number: 1184394

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 2/7/2026.	Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 6215784

HYATT REGENCY CLEARWATER RESORT AND SPA

License Type: Lodging

301 S GULFVIEW BLVD , CLEARWATER BEACH 33767

Insp Date: 05/07/2026

Inspection Number: 1186823

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2026-05-07: **Time Extended**	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Seminole

License Number: 6900381

OPAL HOTEL & SUITES

License Type: Lodging

230 W SR 436 , ALTAMONTE SPRINGS 32714

Insp Date: 05/04/2026

Inspection Number: 1246114

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.-boiler 063625 expired 4/15/21, unable to issue certificate per latest entry on State Fire Marshall website.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6903814

WESTLAKE APARTMENTS

License Type: Lodging

1000 CARDINAL COVE CIR , SANFORD 32771

Insp Date: 05/05/2026

Inspection Number: 1627558

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

02-04-4

Gasoline powered equipment stored inside maintenance facility. For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Seminole

License Number: 6904060

WATERVUE AT LONGWOOD APARTMENT HOMES

License Type: Lodging

907 TIDEWATER LANE #123 , LONGWOOD 32750

Insp Date: 05/05/2026

Inspection Number: 1632725

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6904085

VINTAGE LAKE MARY

License Type: Lodging

2480 CHERRY LAUREL DR , SANFORD 32771

Insp Date: 05/01/2026

Inspection Number: 1631909

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-main office building, operator states repairs are ongoing **Corrective Action Taken** **Repeat Violation**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7403476

OASIS APARTMENTS

License Type: Lodging

1250 WOODCREST DRIVE , DAYTONA BEACH 32114

Insp Date: 05/05/2026

Inspection Number: 1643300

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.- by apartment 5106

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7403476

OASIS APARTMENTS

License Type: Lodging

1250 WOODCREST DRIVE , DAYTONA BEACH 32114

Insp Date: 05/05/2026

Inspection Number: 1643300

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-Building 6 trouble light and trouble battery light on - manager called tech	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 7401047

1915 BEACH CLUB

License Type: Lodging

1915 N ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 05/05/2026

Inspection Number: 1245541

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-03-4	Smoke detector/alarm in guest room/unit damaged or otherwise non functioning as to appear to be inoperable. For reporting purposes only.-unit 6 **Warning**	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 7401486

SUPER INN

License Type: Lodging

1515 SOUTH RIDGEWOOD AVE , DAYTONA BEACH 32114

Insp Date: 05/06/2026

Inspection Number: 1244991

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-03-4	Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only.- Room 111 cover to smoke detector missing	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7403476

OASIS APARTMENTS

License Type: Lodging

1250 WOODCREST DRIVE , DAYTONA BEACH 32114

Insp Date: 05/05/2026

Inspection Number: 1643300

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-04-4	Fire alarm control panel has no power. For reporting purposes only.-building 7 and 2 Manager called tech	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 7400778

SURFSIDE EXECUTIVE APTS

License Type: Lodging

421 AUBURN DR , DAYTONA BCH 83254

Insp Date: 05/06/2026

Inspection Number: 1642943

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.-glass panel box near unit 3 on wall, no breaking device	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 7406511

COURTYARD DELAND HISTORIC DOWNTOWN

License Type: Lodging

308 N WOODLAND BLVD , DELAND 32720

Insp Date: 05/06/2026

Inspection Number: 1188351

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Part is on order.	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7403476

OASIS APARTMENTS

License Type: Lodging

1250 WOODCREST DRIVE , DAYTONA BEACH 32114

Insp Date: 05/06/2026

Inspection Number: 1643300

Insp Type: Routine - Lodging

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

01-06-4

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.- by apartment 5106 - From follow-up inspection 2026-05-06:

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7403476

OASIS APARTMENTS

License Type: Lodging

1250 WOODCREST DRIVE , DAYTONA BEACH 32114

Insp Date: 05/06/2026

Inspection Number: 1643300

Insp Type: Routine - Lodging

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-Building 6 trouble light and trouble battery light on - manager called tech - From follow-up inspection 2026-05-06: Unable to assess

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7403476

OASIS APARTMENTS

License Type: Lodging

1250 WOODCREST DRIVE , DAYTONA BEACH 32114

Insp Date: 05/06/2026

Inspection Number: 1643300

Insp Type: Routine - Lodging

Disposition: Call Back - Extension given, pending

Violation Code

Observation

Violation Citation

04-04-4	- From initial inspection : Fire alarm control panel has no power. For reporting purposes only.-building 7 and 2 Manager called tech - From follow-up inspection 2026-05-06: Unable to assess	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

License Number: 7400503

BAYMONT BY WYNDHAM

License Type: Lodging

2725 W INTERNATIONAL SPWY BLVD , DAYTONA BEACH 32114

Insp Date: 05/05/2026

Inspection Number: 1246563

Insp Type: Complaint Partial

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-fire alarm and alarm silenced lights on - From follow-up inspection 2026-05-05: **Time Extended**	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--