



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Bay

License Number: 1305101

RADISSON PANAMA CITY BEACH

License Type: Lodging

15325 FRONT BEACH RD , PANAMA CITY BCH 32413

Insp Date: 07/30/2026

Inspection Number: 1249281

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1305244

SPRINGHILL SUITS PANAMA CITY BEACH BEACHFRONT

License Type: Lodging

12513 FRONT BEACH RD , PANAMA CITY BEACH 32407

Insp Date: 07/28/2026

Inspection Number: 1191341

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Brevard

License Number: 1500324

MOTEL 6 - COCOA BEACH

License Type: Lodging

3701 N ATLANTIC AVE , COCOA BEACH 32931

Insp Date: 07/30/2026

Inspection Number: 1249279

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By room 274

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1505720

FAIRFEILD INN & SUITES BY MARRIOTT

License Type: Lodging

2450 N HWY A1A , MELBOURNE 32903

Insp Date: 07/24/2026

Inspection Number: 1192028

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Charlotte

License Number: 1801421

HAMPTON INN

License Type: Lodging

24480 SANDHILL BLVD , PORT CHARLOTTE 33983

Insp Date: 07/30/2026

Inspection Number: 1189955

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Jurisdiction No. 093953, Expiration: 06/14/2026.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329230

**BEST WESTERN PLUS MIAMI INTERNATIONAL AIRPORT
HOTEL & SUITES**

License Type: Lodging

4100 W FLAGLER ST , MIAMI 33134

Insp Date: 07/27/2026

Inspection Number: 1192076

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Dade

License Number: 2331530

TERRAZUL

License Type: Lodging

700 SW 107TH , MIAMI 33174

Insp Date: 07/30/2026

Inspection Number: 1667719

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.Observed trouble light on.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2331530

TERRAZUL

License Type: Lodging

700 SW 107TH , MIAMI 33174

Insp Date: 07/30/2026

Inspection Number: 1667719

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Dade

License Number: 2329281

LESLIE HOTEL

License Type: Lodging

1244 OCEAN DR , MIAMI BEACH 33139

Insp Date: 07/27/2026

Inspection Number: 1192093

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

01-05-4

Observation

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed fire extinguishers first, second floor unable to open by pulling on the handle.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2306734

SAN JUAN HOTEL

License Type: Lodging

1680 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 07/29/2026

Inspection Number: 1191480

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

04-01-4

Observation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Dade

License Number: 2329237

ELEMENT MIAMI INTERNATIONAL AIRPORT

License Type: Lodging

3525 NW 25 ST , MIAMI 33142

Insp Date: 07/29/2026

Inspection Number: 1190687

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329315

HYATT PLACE MIAMI AIRPORT EAST

License Type: Lodging

3549 NW LEJEUNE RD , MIAMI SPRINGS 33142

Insp Date: 07/29/2026

Inspection Number: 1191947

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Dade

License Number: 2329531

CITIZENM HOTELS

License Type: Lodging

1200 LINCOLN RD , MIAMI BEACH 33139

Insp Date: 07/30/2026

Inspection Number: 1192312

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328318

BEST WESTERN PLUS ATLANTIC BEACH RRSORT

License Type: Lodging

4101 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 07/30/2026

Inspection Number: 1190037

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificates FL095074 and 095075 expired since 8/10/2025

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Dade

License Number: 2304345

HOLIDAY INN MIAMI BEACH OCEANFRONT

License Type: Lodging

4333 COLLINS AVE , MIAMI BEACH 33140

Insp Date: 07/29/2026

Inspection Number: 1191895

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329531

CITIZENM HOTELS

License Type: Lodging

1200 LINCOLN RD , MIAMI BEACH 33139

Insp Date: 07/30/2026

Inspection Number: 1192312

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed #1 Serial 2318133877469 and #2 Serial 231813387746 both are gas and operate on 800,000 BTUs.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Dade

License Number: 2329958

COURTSIDE FAMILY APARTMENTS

License Type: Lodging

1699 NW 4 AVE , MIAMI 33136

Insp Date: 07/27/2026

Inspection Number: 1638626

Insp Type: Routine - Lodging

Disposition: Call Back - Extension given,
pending

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2026-07-27: Trouble/alarm light illuminated on the fire alarm control panel. First floor, by the Internet cafe. **Time Extended**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329958

COURTSIDE FAMILY APARTMENTS

License Type: Lodging

1699 NW 4 AVE , MIAMI 33136

Insp Date: 07/28/2026

Inspection Number: 1638626

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2026-07-27: Trouble/alarm light illuminated on the fire alarm control panel. First floor, by the Internet cafe. **Time Extended**
- From follow-up inspection 2026-07-28: Trouble/alarm light illuminated on the fire alarm control panel. **Time Extended**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Dade

License Number: 2300592

VESUVE LLC

License Type: Lodging

1785 SW 13 ST , MIAMI 33145

Insp Date: 07/29/2026

Inspection Number: 1628320

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2026-07-29: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Time Extended**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329964

SOUTH BEACH WEST, LLC

License Type: Lodging

1250 W AVE , MIAMI BEACH 33139

Insp Date: 07/29/2026

Inspection Number: 1627181

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2026-07-29: **Time Extended**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Duval

License Number: 2608269

MALABAR MOTEL & MOBILE HOME PARK

License Type: Lodging

8375 NEW KINGS ROAD , JACKSONVILLE 32219

Insp Date: 07/24/2026

Inspection Number: 1249191

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

07-03-4

Scorch marks around an electrical outlet. For reporting purposes only. Scorch mark observed at top of one outlet near the window in unit #30. Operator states all outlets will be replaced as room is being renovated. **Corrective Action Taken**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613456

SAN JOSE APARTMENTS

License Type: Lodging

7008 PONCE DE LEON AVE , JACKSONVILLE 32217

Insp Date: 07/30/2026

Inspection Number: 1659372

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Fire extinguishers in locked boxes near 7026 2A and 2B missing hammers.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/01/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Duval

License Number: 2608615

MOTEL 6 JACKSONVILLE ORANGE PARK

License Type: Lodging

6107 YOUNGERMAN CIR , JACKSONVILLE 32244

Insp Date: 07/27/2026

Inspection Number: 1249211

Insp Type: Complaint Full

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher on shelf in motel laundry room is in the recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2608615

MOTEL 6 JACKSONVILLE ORANGE PARK

License Type: Lodging

6107 YOUNGERMAN CIR , JACKSONVILLE 32244

Insp Date: 07/27/2026

Inspection Number: 1249211

Insp Type: Complaint Full

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Smoke detector has been removed from the designated area over the bed in available rent ready room #119. Operator installed new smoke detector during inspection. **Corrected On-Site**

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/01/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Hernando

License Number: 3700961

HOLIDAY INN EXPRESS & SUITES

License Type: Lodging

30455 CORTEZ BLVD , BROOKSVILLE 34602

Insp Date: 07/27/2026

Inspection Number: 1190334

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Operator stated when power flickers to property this trouble light appears. Attempted to reset but still remained. Operator started to give alarm company a call.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5603661

COVE

License Type: Lodging

120 MONAHAN DR , FORT WALTON BEACH 32547

Insp Date: 07/29/2026

Inspection Number: 1667810

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only: Apartment 19A - exterior light removed exposing electrical wires.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810140

REXFORD

License Type: Lodging

13001 LAKE CYPRESS CIR , ORLANDO 32828

Insp Date: 07/24/2026

Inspection Number: 1667891

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-03-4

Smoke detector/alarm in room/unit damaged as to appear to be inoperable. For reporting purposes only.Kitchen area .

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Orange

License Number: 5806331

EMBASSY SUITES RESORT LAKE BUENA VISTA

License Type: Lodging

8100 LAKE AVE , ORLANDO 32836

Insp Date: 07/31/2026

Inspection Number: 1192771

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificate has expired 135949 2/13/2026.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810198

HILTON GARDEN INN ORLANDO SEA WORLD

License Type: Lodging

6850 WESTWOOD BLVD , ORLANDO 32821

Insp Date: 07/30/2026

Inspection Number: 1192162

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5808459

AMARA AT METROWEST

License Type: Lodging

6168 RALEIGH STREET , ORLANDO 32835

Insp Date: 07/27/2026

Inspection Number: 1661880

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only.-outside lobby entrance

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Orange

License Number: 5808887

RAMADA SUITES ORLANDO INTERNATIONAL AIRPORT

License Type: Lodging

7500 AUGUSTA NATIONAL DR , ORLANDO 32822

Insp Date: 07/29/2026

Inspection Number: 1192736

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.Room 215 **Repeat Violation**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5803730

BEST WESTERN ORLANDO GATEWAY HOTEL

License Type: Lodging

7299 UNIVERSAL BLVD , ORLANDO 32819

Insp Date: 07/28/2026

Inspection Number: 1249239

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.FL 135459, expired 4-3-26

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Pinellas

License Number: 6201541

UPTOWN SUITES

License Type: Lodging

1501 9 ST N , ST. PETERSBURG 33704

Insp Date: 07/30/2026

Inspection Number: 1249260

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.Boiler certificate posted expired 2/16/2025 - From follow-up inspection 2026-07-30: **Time Extended**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6201541

UPTOWN SUITES

License Type: Lodging

1501 9 ST N , ST. PETERSBURG 33704

Insp Date: 07/29/2026

Inspection Number: 1249260

Insp Type: Complaint Full

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.Boiler certificate posted expired 2/16/2025

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/01/2026

Sarasota

License Number: 6803696

AMERICA'S BEST VALUE INN AND SUITES

License Type: Lodging

14000 TAMIAMI TRAIL , NORTH PORT 34287

Insp Date: 07/28/2026

Inspection Number: 1248519

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing hammers to break glass for the extinguisher boxes near room 203, the top of the stairwell between rooms 204 and 205, near room 206, and between 208 and 209.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6804758

WESTIN SARASOTA

License Type: Lodging

1175 N GULFSTREAM AVE , SARASOTA 34236

Insp Date: 07/29/2026

Inspection Number: 1191210

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 133572 1/8/26 133570 1/8/26 133574 1/8/26 133575 1/8/26 140108 1/8/26

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/01/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Volusia

License Number: 7406737

FL LAND TRUST H612

License Type: Lodging

612 NORTH HALIFAX AVE , DAYTONA BEACH 32118

Insp Date: 07/28/2026

Inspection Number: 1667986

Insp Type: Lodging-Licensing Inspection

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

06-02-4

Stairway/fire exit is obstructed. For reporting purposes only.-main entrance, stairway obstructed by wire hanging sign draped across the stairway. Advising operator that no trespassing sign postings are available in other methods that do not cause a major trip hazard at the stairway.-back of establishment, stairway on far north end obstructed by 5 gallon bucket in middle of steps of stairway

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401756

ECONO INN

License Type: Lodging

1567 N US HWY 1 , ORMOND BEACH 32174

Insp Date: 07/29/2026

Inspection Number: 1248554

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only.-outlet missing cover and has scorch mark at first floor, west side of building (exterior).

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401632

HOLIDAY INN RESORT DAYTONA BEACH OCEAN FRONT

License Type: Lodging

1615 S ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 07/30/2026

Inspection Number: 1244614

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-panel behind lobby - From follow-up inspection 2026-07-30: -fire insurance company on site looking into control panel, per management **Time Extended**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.