



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Alachua

License Number: 1100015

QUALITY INN

License Type: Lodging

7516 W NEWBERRY RD , GAINESVILLE 32606

Insp Date: 08/17/2026

Inspection Number: 1248964

Insp Type: Routine - Lodging

Disposition: Administrative complaint
recommended

Violation Code

Observation

Violation Citation

01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. In front of 117, 129, 115, 127.	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

License Number: 1620935

FAIRFIELD INN AND SUITES DEERFIELD BEACH

License Type: Lodging

301 HILLSBORO TECHNOLOGY DR , DEERFIELD BEACH 33441

Insp Date: 08/14/2026

Inspection Number: 1191281

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No
Further Action

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel in front lobby. For reporting purposes only.	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--



Report Date: 08/22/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Collier

License Number: 2102700

WOODSPRING SUITES NAPLES EAST

License Type: Lodging

3786 WHITE LAKE BLVD , NAPLES 34117

Insp Date: 08/19/2026

Inspection Number: 1190178

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only. Observed alarm sounding on fire panel. Operator stated technician is coming to repair system.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2306730

SHERRY FRONTENAC HOTEL

License Type: Lodging

6565 COLLINS AVE , MIAMI BEACH 14613

Insp Date: 08/17/2026

Inspection Number: 1193020

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed light in trouble at the panel located inside front desk office.
Repeat Violation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2331505

14TH PLACE LLC

License Type: Lodging

7136 NW 14 PLACE , MIAMI 33147

Insp Date: 08/14/2026

Inspection Number: 1668098

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-05-4

No smoke detector provided in guest room/unit. For reporting purposes only. Observed fire detector inside unit 7 not functioning.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Dade

License Number: 2306730

SHERRY FRONTENAC HOTEL

License Type: Lodging

6565 COLLINS AVE , MIAMI BEACH 14613

Insp Date: 08/17/2026

Inspection Number: 1193020

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed expired boiler certificates since FL 059292, 057119 08/17/2025
Repeat Violation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329201

METROPOLE HOTEL

License Type: Lodging

635 COLLINS AVE , MIAMI BEACH 33139

Insp Date: 08/17/2026

Inspection Number: 1193043

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed on second floor across from elevator fire extinguisher in recharge zone..

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Dade

License Number: 2329186

MONDRIAN SOUTH BEACH

License Type: Lodging

1100 WEST AVE , MIAMI BEACH 33139

Insp Date: 08/19/2026

Inspection Number: 1193069

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed at lobby fire panel flashing trouble light.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2307426

BAYSIDE APARTMENTS

License Type: Lodging

1085 94 ST , BAY HARBOR ISLANDS 33154

Insp Date: 08/14/2026

Inspection Number: 1650135

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Missing breaking device for 2 extinguishers back of the building.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Dade

License Number: 2329365

WINGATE BY WYNDHAM MIAMI AIRPORT

License Type: Lodging

3755 NW 78 AVE , DORAL 33166

Insp Date: 08/17/2026

Inspection Number: 1191831

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328942

FOUR SEASONS HOTEL MIAMI

License Type: Lodging

1435 BRICKELL AVE , MIAMI 33131

Insp Date: 08/20/2026

Inspection Number: 1192215

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Dade

License Number: 2328266

EXTENDED STAY AMERICA PREMIER STE (#1600)

License Type: Lodging

8655 NW 21 TERRACE , MIAMI 33122

Insp Date: 08/21/2026

Inspection Number: 1191454

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329183

COURTYARD BY MARRIOTT MIAMI DOLPHIN MALL

License Type: Lodging

11275 NW 12 ST , MIAMI 33172

Insp Date: 08/18/2026

Inspection Number: 1189910

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Dade

License Number: 2329190

EPIC HOTEL

License Type: Lodging

270 BISCAYNE BLVD WAY , MIAMI 33131

Insp Date: 08/14/2026

Inspection Number: 1191843

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 2-15-2021

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2326398

HAMPTON INN MIAMI - AIRPORT WEST

License Type: Lodging

3620 NW 79 AVE , DORAL 33166

Insp Date: 08/19/2026

Inspection Number: 1190114

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Dade

License Number: 2326398

HAMPTON INN MIAMI - AIRPORT WEST

License Type: Lodging

3620 NW 79 AVE , DORAL 33166

Insp Date: 08/19/2026

Inspection Number: 1190114

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-03-4

Observation

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310529

F R B CORP

License Type: Lodging

1600 NW NORTH RIVER DR , MIAMI 52669

Insp Date: 08/14/2026

Inspection Number: 1637025

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

01-01-4

Observation

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed overcharged; next to unit 303. - From follow-up inspection 2026-08-14: **Time Extended**

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Dade

License Number: 2329770

GREEN TURNKEY PLAZA LTD

License Type: Lodging

1500 NW 7 CT , MIAMI 33136

Insp Date: 08/17/2026

Inspection Number: 1633011

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

02-08-4

- From initial inspection : Observed BBQ stored under a stairwell. For reporting purposes only. Removed where needed. - From follow-up inspection 2026-08-17:

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3913649

WEST WING BOUTIQUE HOTEL

License Type: Lodging

2501 E FOWLER , TAMPA 33612

Insp Date: 08/20/2026

Inspection Number: 1192625

Insp Type: Complaint Full

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2026-08-04: ****Time Extended**** - From follow-up inspection 2026-08-20: ****Time Extended****

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Lee

License Number: 4604781

DIAMONDHEAD BEACH RESORT LLC

License Type: Lodging

2000 ESTERO BLVD , FT MYERS BCH 33931

Insp Date: 08/18/2026

Inspection Number: 1189897

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Operator is currently servicing fire alarm system.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5100643

SANDPIPER INN

License Type: Lodging

5451 GULF OF MEXICO DR , LONGBOAT KEY 34228

Insp Date: 08/14/2026

Inspection Number: 1246818

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed their front walkway fire extinguisher in the recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Marion

License Number: 5200252

DIXIE MOTEL

License Type: Lodging

1539 S PINE AVE , OCALA 34471

Insp Date: 08/19/2026

Inspection Number: 1248176

Insp Type: Routine - Lodging

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.No smoke alarm inside room #17.

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5200252

DIXIE MOTEL

License Type: Lodging

1539 S PINE AVE , OCALA 34471

Insp Date: 08/19/2026

Inspection Number: 1248176

Insp Type: Routine - Lodging

Disposition: Administrative
recommended

complaint

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.No working hearing impaired smoke detector available at establishment. Manager provided a Gentex hearing impaired smoke detector with a nonfunctional flashing light. The establishment is currently on open warning to obtain a working hearing impaired smoke detector at the time of this inspection.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Orange

License Number: 5803609

ORLANDO INTERNATIONAL DRIVE NORTH HOTEL

License Type: Lodging

5859 AMERICAN WAY , ORLANDO 32819

Insp Date: 08/19/2026

Inspection Number: 1247581

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By back exit near restrooms

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810901

WINGATE INN @ ORLANDO INT'L AIRPORT

License Type: Lodging

5750 HAZELTINE NATIONAL DR , ORLANDO 32822

Insp Date: 08/18/2026

Inspection Number: 1189958

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Room 502 @ 8:37am

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Orange

License Number: 5809868

EMBASSY SUITES ORLANDO DOWNTOWN

License Type: Lodging

191 E PINE ST , ORLANDO 32801

Insp Date: 08/18/2026

Inspection Number: 1189956

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

08-03-4

Observation

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Violation Citation

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6014067

HYATT PLACE BOCA RATON

License Type: Lodging

100 E PALMETTO PARK RD , BOCA RATON 33432

Insp Date: 08/21/2026

Inspection Number: 1190905

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

04-01-4

Observation

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Violation Citation

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Pinellas

License Number: 6203506

SUNCOAST MOTEL

License Type: Lodging

10264 GULF BLVD , TREASURE ISLAND 64893

Insp Date: 08/19/2026

Inspection Number: 1247873

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Fire extinguisher in employee laundry room.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6203506

SUNCOAST MOTEL

License Type: Lodging

10264 GULF BLVD , TREASURE ISLAND 64893

Insp Date: 08/19/2026

Inspection Number: 1247873

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. The inspector and operator tested two separate Gentex hearing impaired smoke detectors, one that plugs into an outlet and the other was battery powered. No visual signaling light was observed going off on either smoke detectors during the inspection. **Warning**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Pinellas

License Number: 6215777

SUNCOAST BEACH VILLAS

License Type: Lodging

10232 GULF BLVD , TREASURE ISLAND 33706

Insp Date: 08/19/2026

Inspection Number: 1247913

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. The inspector and operator tested two separate Gentex hearing impaired smoke detectors, one that plugs into an outlet and the other was battery powered. No visual signaling light was observed going off on either smoke detectors during the inspection. **Warning**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215832

CANDLEWOOD SUITES SAFETY HARBOR

License Type: Lodging

2471 MCMULLEN BOOTH RD , CLEARWATER 33759

Insp Date: 08/17/2026

Inspection Number: 1192373

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel located in the electrical room on the first floor. For reporting purposes only. **Repeat Violation**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Sarasota

License Number: 6804704

HOLIDAY INN EXPRESS & SUITES SARASOTA EAST/I-75

License Type: Lodging

5730 GANTT RD , SARASOTA 34233

Insp Date: 08/21/2026

Inspection Number: 1189969

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble in panel at front desk.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6804033

QUALITY INN

License Type: Lodging

5778 CLARK RD , SARASOTA 34233

Insp Date: 08/14/2026

Inspection Number: 1191317

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/22/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

St. Lucie

License Number: 6602406

SANCTUARY AT WINTERLAKES

License Type: Lodging

5410 NW RABBIT RUN WAY , PORT ST LUCIE 34986

Insp Date: 08/21/2026

Inspection Number: 1668178

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Unable to see alarm. Alarm is beeping. **Repeat Violation**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6602527

GERMAN-AMERICAN TRADING & TOURISM

License Type: Lodging

2510 TAMARIND DR , FT PIERCE 34949

Insp Date: 08/18/2026

Inspection Number: 1668125

Insp Type: Complaint Full

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only. Wire exposed in metal pipe in between units

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7403762

TROPICAL WINDS HOTEL

License Type: Lodging

1398 N ATLANTIC AVE , DAYTONA BEACH 32118

Insp Date: 08/17/2026

Inspection Number: 1192976

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

06-03-4

Marked exit is inaccessible. For reporting purposes only.- door marked for fire exit on south side of ground level, "out order"(automatic opening door)

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting*FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS***Volusia**

License Number: **BIG O TRUST 3-5-20 - TR**
License Type: Lodging 2593 N OLEANDER AVE , DAYTONA BEACH 32118
Insp Date: 08/20/2026 Inspection Number: 1668171 Insp Type: Lodging-Licensing Inspection Disposition: Warning Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-01-4	Damaged electrical wire(s). For reporting purposes only.-from prior mounted light fixture, backside of building on south end 2nd floor	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400060 **SANDALS INN**
License Type: Lodging 133 S OCEAN AVE , DAYTONA BEACH 32118
Insp Date: 08/17/2026 Inspection Number: 1248798 Insp Type: Routine - Lodging Disposition: Warning Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.-unit on wall near 220 missing breaking device	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400060 **SANDALS INN**
License Type: Lodging 133 S OCEAN AVE , DAYTONA BEACH 32118
Insp Date: 08/17/2026 Inspection Number: 1248798 Insp Type: Routine - Lodging Disposition: Warning Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-07-4	Flammable chemicals stored near a source of ignition. For reporting purposes only.-wood material near open vent above gas water heater	Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Volusia

License Number: 7406802

SELENE TOMOKA VILLAGE

License Type: Lodging

1610 N CLYDE MORRIS BLVD , DAYTONA BEACH 32117

Insp Date: 08/20/2026

Inspection Number: 1668164

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-buildings 8, 10 and 11.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406514

DAYTONA AUTOGRAPH COLLECTION

License Type: Lodging

1870 VICTORY CIR , DAYTONA BEACH 32114

Insp Date: 08/18/2026

Inspection Number: 1189999

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-supervisor light on . Per maintenance it's an issue with elevator make a noise .

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Volusia

License Number: 7400765

WLW CAPITAL LLC

License Type: Lodging

3738 S ATLANTIC AVE , DAYTONA BEACH SHORES 32118

Insp Date: 08/18/2026

Inspection Number: 1246980

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

06-02-4

Door marked as an exit is blocked. For reporting purposes only.-path to fire exit from unit 14 door is blocked by a temporary gate

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400765

WLW CAPITAL LLC

License Type: Lodging

3738 S ATLANTIC AVE , DAYTONA BEACH SHORES 32118

Insp Date: 08/18/2026

Inspection Number: 1246980

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.-large black electrical wire from pole connection fed across back parking area into utility box near maintenance door

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/22/2026

Volusia

License Number: 7405533

RIVER WALK GARDEN APARTMENTS LLC

License Type: Lodging

2190 S PALMETTO , SOUTH DAYTONA 32119

Insp Date: 08/19/2026

Inspection Number: 1665481

Insp Type: Routine - Lodging

Disposition: Administrative complaint
recommended

Violation Code

01-02-4

Observation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. in front of unit 10.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.