



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Alachua

License Number: 1103078

Varsity House Gainesville

License Type: Lodging

1720 SW 37TH ST , GAINESVILLE 32607

Insp Date: 08/24/2026

Inspection Number: 1667965

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

01-02-4

Observation

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By unit 341.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Brevard

License Number: 1505915

SEMINOLE RENTALS GROUP LLC

License Type: Lodging

204 WEST SEMINOLE AVE , MELBOURNE 32901

Insp Date: 08/25/2026

Inspection Number: 1657722

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. By apartment #3

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1505593

HOLIDAY INN EXPRESS COCOA

License Type: Lodging

301 TUCKER LN , COCOA 32926

Insp Date: 08/26/2026

Inspection Number: 1191212

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Broward

License Number: 1609861

WESTIN BEACH RESORT FORT LAUDERDALE

License Type: Lodging

321 N FORT LAUDERDALE BEACH BLVD , FORT LAUDERDALE 33304

Insp Date: 08/24/2026

Inspection Number: 1190265

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 3 of 4 certificates

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1618409

EXTENDED STAY AMERICA SUITES #328

License Type: Lodging

1200 FAU RESEARCH PARK BLVD , DEERFIELD BEACH 33441

Insp Date: 08/28/2026

Inspection Number: 1191837

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired, expired 9/22/24. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Broward

License Number: 1610129

LA QUINTA INN & SUITES

License Type: Lodging

3701 UNIVERSITY DR , CORAL SPRINGS 33065

Insp Date: 08/27/2026

Inspection Number: 1193232

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Both expired 3-13-26

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1613440

COURTYARD FORT LAUDERDALE NORTH/CYPRESS CREEK

License Type: Lodging

2440 W CYPRESS CREEK RD , FORT LAUDERDALE 33309

Insp Date: 08/24/2026

Inspection Number: 1191913

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed in laundry room

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Broward

License Number: 1620877

CHATEAU MAR GOLF RESORT

License Type: Lodging

3501 INVERRARY BLVD , LAUDERHILL 33319

Insp Date: 08/28/2026

Inspection Number: 1189998

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.1/30/2026

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number:

72 PARK MIAMI BEACH BY NOMADA

License Type: Lodging

580 72ND ST , MIAMI BEACH 33141

Insp Date: 08/24/2026

Inspection Number: 1192702

Insp Type: Lodging-Licensing Inspection

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Dade

License Number: 2303092

HOLIDAY INN HOTEL

License Type: Lodging

1111 S ROYAL POINCIANA , MIAMI SPGS 67318

Insp Date: 08/26/2026

Inspection Number: 1247858

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.Observed boiler certificates expired on 7/1/2022.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2305265

BEACON HOTEL

License Type: Lodging

720 OCEAN DR , MIAMI BEACH 33139

Insp Date: 08/24/2026

Inspection Number: 1193153

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.Observed at front desk fire panel with the trouble light on. **Repeat Violation**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Dade

License Number: 2301703

ISLAND HOUSE

License Type: Lodging

1428 COLLINS AVE , MIAMI BEACH 94102

Insp Date: 08/28/2026

Inspection Number: 1191130

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328452

COURTYARD BY MARRIOTT

License Type: Lodging

1530 WASHINGTON AVE , MIAMI BEACH 33139

Insp Date: 08/28/2026

Inspection Number: 1191465

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Dade

License Number: 2329270

GRAND BEACH HOTEL SURFSIDE

License Type: Lodging

9449 COLLINS AVE , SURFSIDE 33154

Insp Date: 08/26/2026

Inspection Number: 1189936

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329375

RESIDENCE INN BY MARRIOTT (SUNNY ISLES)

License Type: Lodging

17700 COLLINS AVENUE , SUNNY ISLES 33160

Insp Date: 08/27/2026

Inspection Number: 1191226

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Dade

License Number: 2329325

EUROSTARS LANGFORD

License Type: Lodging

121 SE 1 ST , MIAMI 33131

Insp Date: 08/24/2026

Inspection Number: 1191891

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329401

UPTOWN SUITES - HOMESTEAD

License Type: Lodging

1071 NE 28 AVE , HOMESTEAD 33033

Insp Date: 08/28/2026

Inspection Number: 1189985

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Dade

License Number: 2328050

WITELAW HOTEL & LOUNGE

License Type: Lodging

808-820 COLLINS AVENUE , MIAMI BEACH 33139

Insp Date: 08/27/2026

Inspection Number: 1190136

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.Observed supervisory light on at fire panel at front desk.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329478

PARK CENTRAL SOUTH BEACH

License Type: Lodging

620-650 OCEAN DR , MIAMI BEACH 33139

Insp Date: 08/27/2026

Inspection Number: 1191724

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.Observed fire panel flashing trouble sign in hallway next to offices.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Dade

License Number: 2328266

EXTENDED STAY AMERICA PREMIER STE (#1600)

License Type: Lodging

8655 NW 21 TERRACE , MIAMI 33122

Insp Date: 08/21/2026

Inspection Number: 1191454

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329270

GRAND BEACH HOTEL SURFSIDE

License Type: Lodging

9449 COLLINS AVE , SURFSIDE 33154

Insp Date: 08/26/2026

Inspection Number: 1189936

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Observed Boiler certificate for 124024 expired as of 1/10/22 & 124023 & 124081 expired as 9/27/24. Per engineer an inspection an inspection was conducted and the establishment is awaiting certificates. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/29/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Dade

License Number: 2329417

MR C

License Type: Lodging

2988 MCFARLANE RD , MIAMI 33133

Insp Date: 08/26/2026

Inspection Number: 1190325

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed certificates expired for 135906, 135907, 135908 EXPIRES: 5/7/2026

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2315280

JW MARRIOTT MIAMI TURNBERRY RESORT & SPA

License Type: Lodging

19999 W COUNTRY CLUB DR , AVENTURA 33180

Insp Date: 08/24/2026

Inspection Number: 1191172

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Dade

License Number: 2322921

LA QUINTA BY WYNDHAM AIRPORT EAST

License Type: Lodging

3501 NW 42 AVE , MIAMI 33142

Insp Date: 08/25/2026

Inspection Number: 1192876

Insp Type: Complaint Full

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired since 8/8/2026 - From follow-up inspection 2026-08-25: As per General Manager, boiler inspection was completed and boiler certificate is currently still pending. **Time Extended**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2323873

GDG INVESTORS LLC

License Type: Lodging

855 SW 7 ST , MIAMI 33130

Insp Date: 08/25/2026

Inspection Number: 1647510

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

01-03-4

- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed extinguisher on the stair step in front of Apt. 7.
- From follow-up inspection 2026-08-25: Observed extinguisher on the stair step in front of Apt. 7. **Time Extended**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Dade

License Number: 2317292

HOLIDAY INN

License Type: Lodging

7707 NW 103 ST , HIALEAH GARDENS 33016

Insp Date: 08/24/2026

Inspection Number: 1189883

Insp Type: Complaint Full

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 133212, Expiration: 10/14/22. ****Repeat Violation****
****Warning**** - From follow-up inspection 2026-08-24: No boiler certificate provided. ****Time Extended****

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310418

VERONA APARTMENTS

License Type: Lodging

9050 NE 8 AVE , MIAMI SHORES 33138

Insp Date: 08/25/2026

Inspection Number: 1628552

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed between units 6-7. - From follow-up inspection 2026-08-25: ****Time Extended****

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Dade

License Number: 2303941

747 PROPERTY, LLC

License Type: Lodging

747 NE 83 TERRACE , MIAMI 33138

Insp Date: 08/27/2026

Inspection Number: 1628752

Insp Type: Routine - Lodging

Disposition: Call Back - Admin. complaint recommended

Violation Code

Observation

Violation Citation

06-01-4

- From initial inspection : Path to area marked as an exit is blocked. For reporting purposes only.Observed at third floor stair way blocked by table and planters. - From follow-up inspection 2026-08-27: **Time Extended**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613196

QUALITY INN OF ORANGE PARK

License Type: Lodging

6135 YOUNGERMAN CIR , JACKSONVILLE 32244

Insp Date: 08/26/2026

Inspection Number: 1248442

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.Fire extinguishers missing from the designated cases at room #125 and #147. **Repeat Violation**

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Hillsborough

License Number: 3911502

EXTENDED STAY AMERICA SELECT SUITES 9643

License Type: Lodging

330 GRAND REGENCY BLVD , BRANDON 33510

Insp Date: 08/27/2026

Inspection Number: 1249580

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3911422

RESIDENCE INN BY MARRIOTT

License Type: Lodging

13420 TELECOM PARKWAY N , TAMPA 33637

Insp Date: 08/25/2026

Inspection Number: 1191841

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed fire extinguisher on the third floor near room 303 being slightly overcharged.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Marion

License Number: 5201252

OCALA HILTON

License Type: Lodging

3600 SW 36 AVE , OCALA 44474

Insp Date: 08/27/2026

Inspection Number: 1192052

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Two new boilers installed, no current report. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5500960

HOLIDAY INN EXPRESS HOTEL & SUITES

License Type: Lodging

76071 SIDNEY PLACE , YULEE 32097

Insp Date: 08/27/2026

Inspection Number: 1189905

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In water heater room, portable fire extinguisher in red recharge zone.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/29/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Orange

License Number: 5809860

HOMEWOOD SUITES BY HILTON MAITLAND

License Type: Lodging

290 SOUTHHALL LN , MAITLAND 32751

Insp Date: 08/26/2026

Inspection Number: 1192925

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5808506

COURTYARD BY MARRIOTT

License Type: Lodging

12000 COLLEGIATE WAY , ORLANDO 32817

Insp Date: 08/27/2026

Inspection Number: 1191470

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Orange

License Number: 5809417

EXTENDED STAY AMERICA PREMIER STE (#1639)

License Type: Lodging

6443 WESTWOOD BLVD. , ORLANDO 32821

Insp Date: 08/27/2026

Inspection Number: 1193233

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 2/7/26

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5803620

HOLIDAY INN ORLANDO AIRPORT

License Type: Lodging

5750 T G LEE BLVD , ORLANDO 32822

Insp Date: 08/26/2026

Inspection Number: 1192112

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble ack flashing Operator is aware of

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Orange

License Number: 5808190

ALVISTA METROWEST

License Type: Lodging

2207 LAKE DEBRA DR , ORLANDO 32835

Insp Date: 08/28/2026

Inspection Number: 1657372

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-panel in lobby

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811464

MILLENNIUM METROWEST

License Type: Lodging

6900 PIAZZA GRANDE AVE COMMUNITY MGR, ORLANDO 32835

Insp Date: 08/26/2026

Inspection Number: 1649150

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6014067

HYATT PLACE BOCA RATON

License Type: Lodging

100 E PALMETTO PARK RD , BOCA RATON 33432

Insp Date: 08/21/2026

Inspection Number: 1190905

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Palm Beach

License Number: 6014091

WOODSPRING SUITES PALM SPRINGS - WEST PALM BEACH

License Type: Lodging

2645 10TH AVE N 10TH AVE N, PALM SPRINGS 33461

Insp Date: 08/28/2026

Inspection Number: 1191429

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel at front desk area. For reporting purposes only.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6014059

HOLIDAY INN EXPRESS LANTANA

License Type: Lodging

1251 HYPOLUXO RD , LANTANA 33462

Insp Date: 08/28/2026

Inspection Number: 1191116

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. In rooms 203, 204.

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Palm Beach

License Number: 6014061

RESIDENCE INN WEST PALM BEACH DOWNTOWN

License Type: Lodging

455 HIBISCUS ST , WEST PALM BEACH 33401

Insp Date: 08/28/2026

Inspection Number: 1191615

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6206228

CRAWFORD RENTAL PROPERTIES LLC

License Type: Lodging

7650 COQUINA WAY , ST.PETE BEACH 33706

Insp Date: 08/28/2026

Inspection Number: 1667963

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher on wall in between unit 5 & 6.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/29/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Polk

License Number: 6301721

4700 WIBM LLC

License Type: Lodging

1255 S LAKESHORE WAY , LAKE ALFRED 33850

Insp Date: 08/24/2026

Inspection Number: 1249548

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.Room 2

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6301721

4700 WIBM LLC

License Type: Lodging

1255 S LAKESHORE WAY , LAKE ALFRED 33850

Insp Date: 08/24/2026

Inspection Number: 1249548

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.Room 2

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Polk

License Number: 6301721 **4700 WIBM LLC**
License Type: Lodging 1255 S LAKESHORE WAY , LAKE ALFRED 33850

Insp Date: 08/24/2026 Inspection Number: 1249548 Insp Type: Complaint Full Disposition: Warning Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6309169 **HAMPTON INN & SUITES LAKELAND-SOUTH POLK PARKWAY**
License Type: Lodging 3630 LAKESIDE VILLAGE BLVD , LAKELAND 33803

Insp Date: 08/25/2026 Inspection Number: 1193096 Insp Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6804704 **HOLIDAY INN EXPRESS & SUITES SARASOTA EAST/I-75**
License Type: Lodging 5730 GANTT RD , SARASOTA 34233

Insp Date: 08/21/2026 Inspection Number: 1189969 Insp Type: Routine - Lodging Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble in panel at front desk.	Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Seminole

License Number: 6900381

OPAL HOTEL & SUITES

License Type: Lodging

230 W SR 436 , ALTAMONTE SPRINGS 32714

Insp Date: 08/24/2026

Inspection Number: 1249532

Insp Type: Complaint Full

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. #063625 4/15/2021 #098806 4/15/2021 #098805 4/15/2021**Repeat Violation** **Repeat Violation**

Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6904108

RIVERBEND LANDINGS APARTMENT HOMES

License Type: Lodging

3750 ROSEWATER PLACE , SANFORD 32771

Insp Date: 08/26/2026

Inspection Number: 1668233

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-main office building panel

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/29/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Seminole

License Number: 6904109

RIVERBEND LANDINGS APARTMENT HOMES

License Type: Lodging

3750 ROSEWATER PLACE , SANFORD 32771

Insp Date: 08/26/2026

Inspection Number: 1668234

Insp Type: Lodging-Licensing Inspection

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.-main office building panel

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6903762

SPRINGHILL SUITES SANFORD

License Type: Lodging

201 N TOWNE RD , SANFORD 32771

Insp Date: 08/28/2026

Inspection Number: 1248233

Insp Type: Routine - Lodging

Disposition: Call Back - Complied

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation**** - From follow-up inspection 2026-08-28: ****Time Extended****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6903762

SPRINGHILL SUITES SANFORD

License Type: Lodging

201 N TOWNE RD , SANFORD 32771

Insp Date: 08/27/2026

Inspection Number: 1248233

Insp Type: Routine - Lodging

Disposition: Administrative complaint recommended

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Report Date: 08/29/2026

Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

St. Lucie

License Number: 6602406

SANCTUARY AT WINTERLAKES

License Type: Lodging

5410 NW RABBIT RUN WAY , PORT ST LUCIE 34986

Insp Date: 08/21/2026

Inspection Number: 1668178

Insp Type: Complaint Full

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Unable to see alarm. Alarm is beeping. **Repeat Violation**

Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406719

RE EQUITY INVESTMENT GROUP

License Type: Lodging

819 N RIDGEWOOD AVE , DAYTONA BEACH 32114

Insp Date: 08/24/2026

Inspection Number: 1666861

Insp Type: Routine - Lodging

Disposition: Warning Issued

Violation Code

Observation

Violation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored on fire escape landing (roof of laundry room) . For reporting purposes only.

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7405884

HOST INN

License Type: Lodging

315 BELLEVUE AVE , DAYTONA BEACH 32114

Insp Date: 08/25/2026

Inspection Number: 1247469

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

Observation

Violation Citation

02-07-4

Flammable chemicals stored near a source of ignition. For reporting purposes only.-boxes by water heater in second building

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Volusia

License Number: 7405884

HOST INN

License Type: Lodging

315 BELLEVUE AVE , DAYTONA BEACH 32114

Insp Date: 08/25/2026

Inspection Number: 1247469

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

04-02-4

Observation

No smoke detector provided in guest room/unit. For reporting purposes only.-Room 111Do not rent or occupy room 111 until a fully functioning smoke detector is installed **Corrected On-Site**

Violation Citation

Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406507

SCOOT INN

License Type: Lodging

5964 S RIDGEWOOD AVE, , PORT ORANGE 32127

Insp Date: 08/25/2026

Inspection Number: 1248251

Insp Type: Routine - Lodging

Disposition: Inspection Completed - No Further Action

Violation Code

07-01-4

Observation

Damaged electrical wire(s). For reporting purposes only.-damaged wire visible on backside of establishment, north east side behind office, around electrical box

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Division of Hotels & Restaurants

Fire Observations Reporting

FIRE CODE VIOLATIONS OBSERVED IN PUBLIC FOOD SERVICE & LODGING ESTABLISHMENTS

Report Date: 08/29/2026

Walton

License Number: 7601614

ECONO LODGE

License Type: Lodging

90 BUSINESS PARK RD , DEFUNIAK SPRINGS 32435

Insp Date: 08/25/2026

Inspection Number: 1249581

Insp Type: Complaint Full

Disposition: Administrative
recommended

complaint

Violation Code

01-03-4

Observation

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.Observed empty fire extinguisher case between rms 114/115.

Violation Citation

Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.