

Alachua County

License Number: 1102962 AC HOTEL BY MARRIOTT GAINESVILLE
 License Type: Hotel 151 NW 14 ST, GAINESVILLE 32603

Inspection Date: 01/09/2024 Inspection Number: 1173043 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CASEY, KEITH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed: the FACP had a flashing light, at the front desk.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1100132 QUALITY INN GAINESVILLE
 License Type: Motel 3455 SW WILLISTON RD, GAINESVILLE 32608

Inspection Date: 01/08/2024 Inspection Number: 1231395 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CASEY, KEITH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed: lights flashing in the Reception area FACP.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1100353 KAMPUS INN
 License Type: Motel 2820 NW 13 ST, GAINESVILLE 326092832

Inspection Date: 01/08/2024 Inspection Number: 1233176 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: GRODEWALD, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Fire extinguisher missing from box in front of room 176.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2101761

COMFORT INN & EXECUTIVE SUITES

License Type: Motel

3860 TOLL GATE BLVD, NAPLES 34114

Inspection Date: 01/12/2024

Inspection Number: 1233311

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRAVES, PETER

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. The trouble light is lit on the control panel behind the front desk.
Repeat Violation

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2311339 ECONO LODGE INN & SUITES
 License Type: Motel 1223 NE 1 AVE, FLORIDA CITY 33034

Inspection Date: 01/11/2024 Inspection Number: 1233189 Inspection Type: Complaint Full Inspection Disposition: Administrative complaint recommended
 Inspector Name: SAENZ, HILDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Observed at room # 105.	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-01-4	Damaged electrical wire(s). For reporting purposes only. Observed electrical box the wires are exposed.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328937 THE RITZ CARLTON HOTEL COCONUT GROVE
 License Type: Hotel 3300 SW 27TH AVE, COCONUT GROVE 33133

Inspection Date: 01/04/2024 Inspection Number: 1170536 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed The boilers 094548, 094547, 094546, 098780 exp. 6/11/2021 019856, exp. 08/28/2021; 098749 exp. 05-15-2019. 094551 exp. 05-15-2019 out of service.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2610382	BEST WESTERN SOUTHSIDE HOTELS & SUITES		
License Type: Motel	4580 COLLINS RD, JACKSONVILLE 32244		
Inspection Date: 01/08/2024	Inspection Number: 1231287	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PERRY, DENNIS			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguishers by room 206 and 514.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613264	ALOFT JACKSONVILLE TAPESTRY PARK HOTEL		
License Type: Hotel	4812 DEER LAKE DR W, JACKSONVILLE 32246		
Inspection Date: 01/08/2024	Inspection Number: 1173128	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JEFFERS, MARY-BETH			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificate for jurisdiction #136469 expired 1-4-24.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613289	WOODSPRING SUITES JACKSONVILLE CAMPFIELD COMMONS		
License Type: Hotel	11250 LAMBTAIL LN, JACKSONVILLE 32256		
Inspection Date: 01/11/2024	Inspection Number: 1172524	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: BADDING, MELANIE			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light on at fire panel. Person in charge states awaiting replacement.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Flagler County

License Number: 2800144

TOPAZ HOTEL/MOTEL

License Type: Motel

1224 S HWY A1A, FLAGLER BEACH 32136

Inspection Date: 01/10/2024

Inspection Number: 1231173

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: HARTMANN, MICHELLE

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.
 Could not test hearing impaired detector. Could not plug in. ****Warning****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Nassau County

License Number: 5500869

HI LITE EXTENDED STAY

License Type: Motel

553597 US HWY 1, HILLIARD 32046

Inspection Date: 01/11/2024

Inspection Number: 1233194

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: ROZIER, TORRANCE

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.
Electrical panel in Back of building, has electrician coming out

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5809868

EMBASSY SUITES ORLANDO DOWNTOWN

License Type: Hotel

191 E PINE ST, ORLANDO 32801

Inspection Date: 01/09/2024

Inspection Number: 1172747

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WHITE, THOMAS

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810213

FAIRFIELD INN & SUITES ORLANDO INT'L

License Type: Hotel

8214 UNIVERSAL BLVD, ORLANDO 32819

Inspection Date: 01/12/2024

Inspection Number: 1174950

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CLARKE, ALBERT

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811161

HOMEWOOD SUITES ORLANDO CONVENTION CENTER SOUTH

License Type: Hotel

6940 WESTWOOD BLVD, ORLANDO 32821

Inspection Date: 01/11/2024

Inspection Number: 1172615

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PASIECKI, VICTORIA

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811226

CONRAD ORLANDO

License Type: Hotel

1500 EASTBEACH WAY, ORLANDO 32836

Inspection Date: 01/09/2024

Inspection Number: 1173860

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: BACHOO, SAVITRI

Inspection

Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificates or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6012557 THE RESERVE AND PARK AT RIVERBRIDGE (RESERVE)
 License Type: Apartment 50 OLIVE TREE CIR, GREENACRES 33413

Inspection Date: 01/12/2024 Inspection Number: 1580694 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SINGH, GAJENDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-01-4	Damaged electrical wire(s). For reporting purposes only. Emergency light dangling by wire and glass shield missing on one by apartment 425 (building 4)	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6009710 EAU PALM BEACH RESORT & SPA
 License Type: Hotel 100 S OCEAN BLVD, MANALAPAN 33462

Inspection Date: 01/12/2024 Inspection Number: 1171217 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOLDMAN, BARRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. J#133410 - 09/27/2023	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6008412 HOLIDAY INN - BOCA RATON NORTH
 License Type: Hotel 701 NW 53 ST, BOCA RATON 33487

Inspection Date: 01/11/2024 Inspection Number: 1173586 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: KHATOON, BEGUM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6209371

LA QUINTA INN

License Type: Motel

7500 US HWY 19 N, PINELLAS PARK 33781

Inspection Date: 01/09/2024

Inspection Number: 1229387

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: ROBLES, ELIZABETH

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Yellow fire panel light illuminated on fire panel in front desk area. - From follow-up inspection 2024-01-09: ****Time Extended****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903994

HOME TOWNE STUDIOS

License Type: Hotel

210 N OXFORD RD, CASSELBERRY 32707

Inspection Date: 01/12/2024

Inspection Number: 1175022

Inspection Type: Complaint Full

Inspection Disposition: Administrative
complaint recommended

Inspector Name: VO, STEVE

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only.
- viewed emails showing work order approved to replace whole system.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501346

INN ON CHARLOTTE BED AND BREAKFAST

License Type: Bed and Breakfast

52 CHARLOTTE ST, SAINT AUGUSTINE 32084

Inspection Date: 01/11/2024

Inspection Number: 1095771

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MAKOWSKI, JARED

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.
Observed no smoke alarm in unit 1.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6602508

PINE LAKES PRESERVE

License Type: Apartment

7700 PINE LAKES BLVD, PORT SAINT LUCIE 34952

Inspection Date: 01/11/2024

Inspection Number: 1579959

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: HARROD, JESSICA

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Building 5 both in second hallway, building 6 first hall way both second hall way one towards back, buil

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406599	O&M TAN
License Type: Apartment	938 NORTH GRANDVIEW AVENUE, DAYTONA BEACH 32118
Inspection Date: 01/11/2024	Inspection Number: 1572372
Inspector Name: WOOD, JUSTIN	Inspection Type: Routine - Lodging
	Inspection Disposition: Call Back - Admin. complaint recommended

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-06-4	<p>- From initial inspection : Door marked as an exit locked with a lock that requires a combination/key. For reporting purposes only.</p> <p>-combination locked used at base of stairway that leads up to unit 6 **Warning**</p> <p>- From follow-up inspection 2024-01-</p>	<p>509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

License Number: 7405603	SLEEP INN ORMOND BEACH
License Type: Motel	170 WILLIAMSON BOULEVARD, ORMOND BEACH 32174
Inspection Date: 01/11/2024	Inspection Number: 1231381
Inspector Name: RUTLEDGE, REBECCA	Inspection Type: Routine - Lodging
	Inspection Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	<p>Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.</p>	<p>509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>