

**Brevard County**

License Number: 1501416

QUALITY INN KENNEDY SPACE CENTER

License Type: Motel

3655 CHENEY HWY, TITUSVILLE 32780

Inspection Date: 01/17/2024

Inspection Number: 1233130

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FRANZ, LINDA

Violation Code    Observation

Violation Citation

08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Operator has are invoice from state of Florida fire Marshall from 12-26-23 for services but has not received the report.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Broward County**

License Number: 1600219 SEVER PROPERTIES  
 License Type: Apartment 4010 SW 23 ST, WEST PARK 33023-3437

Inspection Date: 01/18/2024 Inspection Number: 1567813 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PIERRE, ENOSE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to unit 2	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1616961 COURTYARD VILLA  
 License Type: Motel 4312 EL MAR DR, FORT LAUDERDALE 33308

Inspection Date: 01/16/2024 Inspection Number: 1229386 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied  
 Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
05-02-5	- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. - From follow-up inspection 2024-01-16: Per operator, a unit was purchased to be hard wired in Unit 1. **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2302923	INN OF HOMESTEAD		
License Type: Motel	1020 N HOMESTEAD BLVD, HOMESTEAD 33030		
Inspection Date: 01/17/2024	Inspection Number: 1229376	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: SAENZ, HILDA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to unit 110. - From follow-up inspection 2024-01-17: Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to unit 110. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2329489	AC & ELEMENT HOTEL BRICKELL MIAMI		
License Type: Hotel	115 SW 8 ST, MIAMI 33130		
Inspection Date: 01/17/2024	Inspection Number: 1172083	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CABANAS, NATALIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2328942	FOUR SEASONS HOTEL MIAMI		
License Type: Hotel	1435 BRICKELL AVE, MIAMI 33131		
Inspection Date: 01/16/2024	Inspection Number: 1172738	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2331089	GROVE CENTRAL RESIDENCES		
License Type: Apartment	2800 SW 27 TERRACE, MIAMI 33133		
Inspection Date: 01/17/2024	Inspection Number: 1580138	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GRESSEAU, CHRISTINA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Bae red for garage area.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Dade County**

License Number: 2307293 CASITA 80  
 License Type: Apartment 8040 HARDING AVE, MIAMI BEACH 33141

Inspection Date: 01/16/2024 Inspection Number: 1570445 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Alarm is located inside the room ( office / electrical panel ) .	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-06-4	Fire alarm control panel emitting an audible alarm. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329394 CASITA 76  
 License Type: Hotel 7610 HARDING AV, MIAMI BEACH 33141

Inspection Date: 01/16/2024 Inspection Number: 1172399 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed light in trouble inside housekeeping storage next to the laundry.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330023 SAME AS ABOVE  
 License Type: Apartment 1259-1279 NW 58 TERRACE, MIAMI 33142

Inspection Date: 12/21/2023 Inspection Number: 1579533 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SWIGERT, RICHARD Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-04-4	Observed: Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Observed on building 1259 by the laundry room. Priority: Reporting	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2307022

NORGATE APARTMENTS

License Type: Apartment

1237 NE 128 ST, NORTH MIAMI 331615184

Inspection Date: 01/19/2024

Inspection Number: 1580761

Inspection Type: Complaint Full

Inspection Disposition: Administrative complaint recommended

Inspector Name: SUAREZ, LEOPOLDO

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2611652

122 WEST

License Type: Apartment

5537 FIRESTONE RD, JACKSONVILLE 32244

Inspection Date: 01/19/2024

Inspection Number: 1567259

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

06-01-4

Path to door marked as an exit is blocked. For reporting purposes only.  
Stairway serving unit 1C is blocked by tree.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Escambia County**

License Number: 2700772

OYO HOTEL

License Type: Motel

6911 PENSACOLA BLVD, PENSACOLA 32505

Inspection Date: 01/16/2024

Inspection Number: 1233325

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: THARP, MATTHEW A

Violation Code

Observation

Violation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher by room 301.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4	Portable fire extinguisher in disrepair. Fire extinguisher between 319 and 321 has rust on bottom.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hendry County**

License Number: 3600013

AMERICAS BEST VALUE INN

License Type: Hotel

108 ROYAL PALM AVE, CLEWISTON 33440

Inspection Date: 01/18/2024

Inspection Number: 1173423

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: JACKS, ALBERT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.: at unit 204 and 212.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-05-4	No smoke detector provided in guest room/unit. For reporting purposes only unit 212. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Hillsborough County**

License Number: 3912167

OAK CHASE APARTMENTS I

License Type: Apartment

12535 TINSLEY CIR, TAMPA 33612

Inspection Date: 01/17/2024

Inspection Number: 1580347

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: DUNN, MIKAYLA

Violation Code

Observation

Violation Citation

01-03-4      Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. In laundry area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-04-4      Electrical outlet damaged to indicate a malfunction. For reporting purposes only.  
Exposed wiring on lamp near unit 131 12523  
Electrical panel missing at building 12503

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Monroe County**

License Number: 5400347

FISHER INN RESORT

License Type: Motel

84951 OVERSEAS HWY, ISLAMORADA 33036

Inspection Date: 01/19/2024

Inspection Number: 1231060

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: WHITEHURST, SCOTT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
03-01-4	<p>- From initial inspection : No fire sprinkler system installed in a transient lodging establishment three stories or more in height, or over 75 feet in height. For reporting purposes only. The 200 Building is 3 stories and has no sprinkler system installed in the rooms.</p> <p>- From follow-up inspection 2024-01-19: No fire sprinkler system installed in a transient lodging establishment three stories or more in height, or over 75 feet in height. For reporting purposes only. The 200 Building is 3 stories and has no sprinkler system installed in the rooms. **Time Extended**</p>	<p>509.215 and 509.032(2)(d) FS Reporting: 509.215 Any public lodging establishment, as defined in this chapter, which is of three stories or more, or over 75 feet in height shall be equipped with an automatic sprinkler system installed in compliance with the provisions prescribed in the National Fire Protection Association publication NFPA No. 13 "Standards for the Installation of Sprinkler Systems. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

**Orange County**

License Number: 5811138 ALOFT ORLANDO DOWNTOWN HOTEL  
 License Type: Hotel 500 S ORANGE AVE, ORLANDO 32801

Inspection Date: 01/19/2024 Inspection Number: 1170398 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: WHITE, THOMAS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.  Missing certificate for boiler 131932.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5803609 ORLANDO INTERNATIONAL DRIVE HOTEL NORTH  
 License Type: Motel 5859 AMERICAN WAY, ORLANDO 32819

Inspection Date: 01/17/2024 Inspection Number: 1233327 Inspection Type: Complaint Full Inspection Disposition: Warning Issued  
 Inspector Name: KOSTELNY, ROGER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. In lobby	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

License Number: 5913657

PARK ROYAL ORLANDO

License Type: Motel

1500 N THACKER AVE, KISSIMMEE 34741

Inspection Date: 01/19/2024

Inspection Number: 1231296

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: DAVIS, DIANNA

Violation Code

Observation

Violation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Smoke detector in laundry room not hardwired and no lights. Advised to test batteries etc.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6006208

EMBASSY SUITES WEST PALM BEACH AIRPORT HOTEL

License Type: Hotel

1601 BELVEDERE RD, WEST PALM BEACH 33406

Inspection Date: 01/19/2024

Inspection Number: 1170195

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: SINGH, GAJENDRA

Violation Code

Observation

Violation Citation

04-01-4 - From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Main panel by front desk. - From follow-up inspection 2024-01-19: Same \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-06-4 - From initial inspection : Fire alarm control panel emitting an audible alarm. For reporting purposes only. Audible alarm silenced ( based on light indicator ) - From follow-up inspection 2024-01-19: Same. \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Polk County**

License Number: 6301176

STAYABLE SUITES LAKELAND

License Type: Motel

4645 N SOCRUM LOOP RD, LAKELAND 33809

Inspection Date: 01/19/2024

Inspection Number: 1233341

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITE, CHERYL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Room 130	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6903994 HOME TOWNE STUDIOS  
 License Type: Hotel 210 N OXFORD RD, CASSELBERRY 32707

Inspection Date: 01/16/2024 Inspection Number: 1175022 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied  
 Inspector Name: VO, STEVE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-04-4	- From initial inspection : Fire alarm control panel has no power. For reporting purposes only. - viewed emails showing work order approved to replace whole system. - From follow-up inspection 2024-01-16: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6903996 MAA TWIN LAKES  
 License Type: Apartment 11500 MYRTLEWOOD DR, SANFORD 32771

Inspection Date: 01/17/2024 Inspection Number: 1580431 Inspection Type: Complaint Full Inspection Disposition: Warning Issued  
 Inspector Name: JENKINS, ELAINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. -building 5	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7400060 SANDALS INN  
 License Type: Motel 133 S OCEAN AVE, DAYTONA BEACH 32118

Inspection Date: 01/19/2024 Inspection Number: 1231668 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  -on wall next to 102-103. Manager noted that insurance company has been out to schedule replacements/refills.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406519 BAYMONT INN & SUITES  
 License Type: Motel 175 INTERCHANGE BLVD, ORMOND BEACH 32174

Inspection Date: 01/19/2024 Inspection Number: 1229871 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: RUTLEDGE, REBECCA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-04-4	Electrical outlet cover missing at north end of second floor hallway.For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.