

**Alachua County**

License Number: 1102945

COUNTRY INN & SUITES

License Type: Hotel

4015 SW 43 ST, GAINESVILLE 32608

Inspection Date: 02/01/2024

Inspection Number: 1172831

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

Observed: the fire extinguisher in the laundry on the wall, shows it is not fully charged, per the manager, it was used today for a fire outside in the smoking area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Bay County**

License Number: 1305242

HOLIDAY INN EXPRESS

License Type: Hotel

12907 FRONT BEACH RD, PANAMA CITY BEACH 32407

Inspection Date: 02/02/2024

Inspection Number: 1170523

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HAASE, TINA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguishers next to rooms 201 and 220 in recharge.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1505695

EXTENDED STAY AMERICA #9505

License Type: Hotel

4835 HELEN HAUSER BLVD, TITUSVILLE 32780

Inspection Date: 01/31/2024

Inspection Number: 1171739

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: FRANZ, LINDA

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 8/11/22 permit Booo73243 - From follow-up inspection 2024-01-31: \*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2307942 MIAMI INT'L AIRPORT HOTEL  
 License Type: Hotel NW 20TH STREET & LE JEUNE ROAD, MIAMI 33122

Inspection Date: 02/02/2024 Inspection Number: 1172768 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SANCHEZ, JAVIER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed no boiler certification for FL 59146.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2301193 GPW LITTLE HAVANA LLC  
 License Type: Apartment 1528 NW 3 ST, MIAMI 33125

Inspection Date: 01/31/2024 Inspection Number: 1562733 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: SAENZ, HILDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2301114 LA FLORA  
 License Type: Hotel 1238 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 01/29/2024 Inspection Number: 1174758 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: MIRABAL, MAYRELIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2305269 HOTEL CARDOZO  
 License Type: Hotel 1300 OCEAN DR, MIAMI BEACH 33139

Inspection Date: 01/29/2024 Inspection Number: 1172361 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: ASTROQUIZA, MIGUEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Observed trouble/alarm light illuminated on the fire alarm control panel at front counter. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2325175 HOTEL OCEAN  
 License Type: Hotel 1236 OCEAN DR, MIAMI BEACH 33139

Inspection Date: 01/29/2024 Inspection Number: 1172171 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied  
 Inspector Name: ASTROQUIZA, MIGUEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-02-4	- From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only. Observed no smoke detector at room 403. - From follow-up inspection 2024-01-29: Room 403 was not available for inspection. **Time Extended**	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2323650 THE PALMS SOUTH BEACH HOTEL  
 License Type: Hotel 3025 COLLINS AVE, MIAMI BEACH 331404106

Inspection Date: 01/29/2024 Inspection Number: 1170146 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: SUAREZ, LEOPOLDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2330518 GREEN HOUSE APARTMENTS  
 License Type: Apartment 8440 S DIXIE HWY, MIAMI 33143

Inspection Date: 01/30/2024 Inspection Number: 1539508 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied  
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2024-01-30: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. <b>**Time Extended**</b>	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. <b>**Repeat Violation**</b>	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328367 EXTENDED STAY AMERICA #1740  
 License Type: Hotel 3640 SW 22 ST, MIAMI 33145

Inspection Date: 01/29/2024 Inspection Number: 1173437 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Inside the office.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2309154	LUDLAM GARDEN APTS		
License Type: Apartment	6700 SW 44 ST, MIAMI 331554780		
Inspection Date: 01/31/2024	Inspection Number: 1561483	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ELDER, AUDREY			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed near unit 6.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330238	MIRABELLE		
License Type: Apartment	7400 SW 88 ST, MIAMI 33156		
Inspection Date: 01/31/2024	Inspection Number: 1574356	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: LEIDECKER, EDILMA			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed two boiler of 130 gallon on site no certificate available.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2307022	NJZ ENTERPRISES INC		
License Type: Apartment	1237 NE 128 ST, NORTH MIAMI 33161		
Inspection Date: 01/26/2024	Inspection Number: 1580782	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SUAREZ, LEOPOLDO			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





**Lake County**

License Number: 4500220

MISSION INN

License Type: Motel

10400 CR 48, HOWEY-IN-THE-HILLS 34737

Inspection Date: 02/02/2024

Inspection Number: 1229942

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: SULLIVAN, SENJUN

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 3 outdoor boilers, all certificates expired 12/09/23 per <https://www.citizenserve.com/120/CAPFor120?>  
Action=SearchBoilers. Jurisdiction #  
133405  
094694  
094695 - From follow-up inspection 2024-02-02: \*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5801023

WYNDHAM RESORT ORLANDO I-DRIVE

License Type: Motel

8001 INTERNATIONAL DRIVE, ORLANDO 32819

Inspection Date: 02/02/2024

Inspection Number: 1233375

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOSTELNY, ROGER

Violation Code    Observation

Violation Citation

08-01-4            Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.  
Building 9/10. FL093833 4/9/2020

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5803609

ORLANDO INTERNATIONAL DRIVE HOTEL NORTH

License Type: Motel

5859 AMERICAN WAY, ORLANDO 32819

Inspection Date: 01/31/2024

Inspection Number: 1233327

Inspection Type: Complaint Full

Inspection Disposition: Call Back - Extension given, pending

Inspector Name: KOSTELNY, ROGER

Violation Code    Observation

Violation Citation

04-01-4            - From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
In lobby    - From follow-up inspection 2024-01-31: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

---

License Number: 5913650	MOTEL 6 KISSIMMEE - ORLANDO
License Type: Motel	5733 W IRLO BRONSON HWY, KISSIMMEE 34746

Inspection Date: 02/02/2024	Inspection Number: 1232858	Inspection Type: Complaint Full	Inspection Disposition: Call Back - Complied
Inspector Name: SMITH JONES, SHANTASIA			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2023-12-08: <b>**Time Extended**</b> - From follow-up inspection 2023-12-14: <b>**Time Extended**</b> - From follow-up inspection 2024-02-02: <b>**Time Extended**</b>	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

---

License Number: 5912059	MELIA ORLANDO HOTEL AT CELEBRATIONS
License Type: Hotel	225 CELEBRATION PL, CELEBRATION 34747

Inspection Date: 01/31/2024	Inspection Number: 1172784	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: QUIJANO, LAUREN			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-07-4	Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6014336

CASPIAN

License Type: Apartment

190 SE 5 AVE, DELRAY BEACH 33483

Inspection Date: 02/02/2024

Inspection Number: 1577888

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: KHATOON, BEGUM

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6213732		VINOY COURTYARD APARTMENTS	
License Type: Apartment		656 BEACH DR NE, ST. PETERSBURG 33701	
Inspection Date: 01/30/2024	Inspection Number: 1559483	Inspection Type: Lodging-Licensing Inspection	Inspection Disposition: Warning Issued
Inspector Name: HOWEY, JANINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Fire extinguisher on floor front hallway entrance	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 6215784		HYATT REGENCY CLEARWATER BEACH RESORT & SPA	
License Type: Hotel		301 GULF VIEW BLVD, CLEARWATER 33767	
Inspection Date: 02/02/2024	Inspection Number: 1173017	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KOUSTIS, TIMOTHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FI123659, FI123660 expired 7/25/2021 **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 6215812		RESIDENCE INN	
License Type: Hotel		309 CORONADO DRIVE, CLEARWATER 33767	
Inspection Date: 01/29/2024	Inspection Number: 1172911	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: KOUSTIS, TIMOTHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Pinellas County**

License Number: 6215813

SPRINGHILL SUITES

License Type: Hotel

309 CORONADO DR, CLEARWATER 33767

Inspection Date: 01/29/2024

Inspection Number: 1172913

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: KOUSTIS, TIMOTHY

Violation Code

Observation

Violation Citation

04-01-4      Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7406516 LAKESIDE VILLAGE APARTMENTS  
 License Type: Apartment 155 ONTARIO CT, DAYTONA BEACH 32114

Inspection Date: 01/31/2024 Inspection Number: 1580854 Inspection Type: Complaint Full Inspection Disposition: Warning Issued  
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. -trouble light ,panel in office beeping	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406453 CROTON HOUSE II LLC  
 License Type: Bed and Breakfast 470-472 N CAUSEWAY, NEW SMYRNA BEACH 32169

Inspection Date: 01/29/2024 Inspection Number: 1095705 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: PICHARDO, RENEE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.