

**Alachua County**

License Number: 1101922 SUPER 8 MOTEL  
 License Type: Motel 4202 SW 40 BLVD, GAINESVILLE 32608

Inspection Date: 02/20/2024 Inspection Number: 1231758 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CASEY, KEITH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-07-4	Flammable chemicals stored near a source of ignition. For reporting purposes only. Observed: a can of PVC glue stored on the top of the heat producing on demand hot water heater. The can of glue was removed. <b>**Corrected On-Site**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1102958 WOODSPRING SUITES  
 License Type: Hotel 5505 SW 41ST BLVD, GAINESVILLE 32608

Inspection Date: 02/19/2024 Inspection Number: 1173494 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: CASEY, KEITH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Observed: hearing impaired smoke detectors Gentex did not flash when tested. These are new, and have not had the battery attached. The sounder worked, the strobe did not. A battery has been attached to one to see if the system needs to be charged for a period of time, prior to working. There is no cord attached. <b>**Corrective Action Taken**</b>	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1100097 TRAVELER'S INN  
 License Type: Motel 3103 NW 13 ST, GAINESVILLE 326092176

Inspection Date: 02/23/2024 Inspection Number: 1231881 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GRODEWALD, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher in between rooms 231 and 232.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Collier County**

License Number: 2101761

COMFORT INN & EXECUTIVE SUITES

License Type: Motel

3860 TOLL GATE BLVD, NAPLES 34114

Inspection Date: 02/20/2024

Inspection Number: 1231548

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: GRAVES, PETER

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Behind the front desk the trouble/supervisor light is on. - From follow-up inspection 2024-02-20: **\*\*Time Extended\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Columbia County**

License Number: 2200597

WEEKLY INN

License Type: Motel

3816 US 90 W, LAKE CITY 32055

Inspection Date: 02/19/2024

Inspection Number: 1231702

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FORBES, WAYNE

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Extinguisher in front of #5 in red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





**Dade County**

License Number: 2329190		EPIC HOTEL	
License Type: Hotel		270 BISCAYNE BLVD WAY, MIAMI 33131	
Inspection Date: 02/19/2024	Inspection Number: 1173524	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2301745		1235 APARTMENTS	
License Type: Apartment		1235 SW 6 ST, MIAMI 331354053	
Inspection Date: 02/22/2024	Inspection Number: 1499843	Inspection Type: Routine - Lodging	Inspection Disposition: Call Back - Complied
Inspector Name: GATO, RANDY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed missing breaking device in extinguisher box by unit 1. - From follow-up inspection 2024-02-22: Observed missing breaking device in extinguisher box by unit 1. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329956		GONZALEZ RENTAL	
License Type: Apartment		1036 NW 6 ST, MIAMI 33136	
Inspection Date: 02/20/2024	Inspection Number: 1570148	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
06-01-4	Path to door marked as an exit is blocked. For reporting purposes only. Observed buckets on hallways 1st and 2nd floor	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329366		HAMPTON INN AND SUITES MIAMI	
License Type: Hotel		3450 BISCAYNE BLVD, MIAMI 33137	
Inspection Date: 02/23/2024	Inspection Number: 1174349	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ZHANG, JACKY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By room 803 and 829.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	





**Dade County**

License Number: 2329398	GENERATOR	
License Type: Hotel	3120 COLLINS AVENUE, MIAMI BEACH	33140
Inspection Date: 02/22/2024	Inspection Number: 1173438	Inspection Type: Routine - Lodging
Inspector Name: UNZAGA, MILADYS		Inspection Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed FL 135551 and 135552 exp 1/21/2023 **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329463	DCROSS MANAGEMENT	
License Type: Hotel	5445 COLLINS AVENUE UNIT C17, MIAMI BEACH	33140
Inspection Date: 02/23/2024	Inspection Number: 1173693	Inspection Type: Routine - Lodging
Inspector Name: UNZAGA, MILADYS		Inspection Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed at the lobby.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificate FL 092742 expired since 2/16/2024. Inspection was conducted already , but the certificate is pending.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed 2 new boilers already inspected, but not registered.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2303707	SUNSET CLUB APARTMENTS		
License Type: Apartment	6259 SUNSET DR, SOUTH MIAMI 33143		
Inspection Date: 02/20/2024	Inspection Number: 1571007	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: LEIDECKER, EDILMA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. One located next to unit E-13.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2301705	GARDEN APARTMENTS		
License Type: Apartment	2312 SW 17 ST, MIAMI 33145		
Inspection Date: 02/21/2024	Inspection Number: 1574650	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RAMON, JESSICA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device provided near unit 213.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2305082	GABLES INN		
License Type: Motel	730 S DIXIE HWY, CORAL GABLES 331462602		
Inspection Date: 02/19/2024	Inspection Number: 1228887	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: GRESSEAU, CHRISTINA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed between units 216 and 217 , as well as between units 116 and 117, no device available to open extinguishers.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2328337	INTERNATIONAL CLUB APARTMENTS		
License Type: Apartment	1900 SW 122 AVE, MIAMI 33175		
Inspection Date: 02/23/2024	Inspection Number: 1564566	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: RAMON, JESSICA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on building 1850 near unit 507. Observed no breaking device on building 1950 near unit 116.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Duval County**

License Number: 2613481	THE SOUTHERLY AT SOUTHBANK
License Type: Apartment	959 PRUDENTIAL DR, JACKSONVILLE 32207
Inspection Date: 02/21/2024	Inspection Number: 1569264
Inspector Name: ESPINOSA-BECKERT, ILIANA	Inspection Type: Routine - Lodging
	Inspection Disposition: Warning Issued
<u>Violation Code</u>	<u>Observation</u>
02-04-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. In maintenance room, employees removed it <b>**Corrected On-Site**</b>
	<u>Violation Citation</u>
	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613196	QUALITY INN OF ORANGE PARK
License Type: Motel	6135 YOUNGERMAN CIR, JACKSONVILLE 32244
Inspection Date: 02/21/2024	Inspection Number: 1233401
Inspector Name: PERRY, DENNIS	Inspection Type: Complaint Full
	Inspection Disposition: Call Back - Admin. complaint recommended
<u>Violation Code</u>	<u>Observation</u>
05-02-5	- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Detector in room 115 did not work when tested. <b>**Warning**</b> - From follow-up inspection 2024-02-21: Detector still not repaired. <b>**Time Extended**</b>
	<u>Violation Citation</u>
	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2608853	EMBASSY SUITES JACKSONVILLE
License Type: Hotel	9300 BAYMEADOWS RD, JACKSONVILLE 32256
Inspection Date: 02/20/2024	Inspection Number: 1172830
Inspector Name: BADDING, MELANIE	Inspection Type: Routine - Lodging
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light illuminated on fire panel. Person in charge states service due today.
	<u>Violation Citation</u>
	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2609190	MARRIOTT JACKSONVILLE HOTEL
License Type: Hotel	4670 SALISBURY RD, JACKSONVILLE 32256
Inspection Date: 02/22/2024	Inspection Number: 1172842
Inspector Name: BADDING, MELANIE	Inspection Type: Routine - Lodging
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble panel illuminated during inspection. Person in charge is aware and service is scheduled for next week.
	<u>Violation Citation</u>
	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3911366

RUSKIN INN

License Type: Motel

3113 E COLLEGE AVE, RUSKIN 33570

Inspection Date: 02/23/2024

Inspection Number: 1231757

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: CRUZ, JABULANI

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Hearing impaired smoke detector in room 209. Not able to verify any other smoke detectors because they are occupied.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Monroe County**

License Number: 5403172

ISLANDER RESORT

License Type: Hotel

81450 OVERSEAS HWY, ISLAMORADA 33036

Inspection Date: 02/22/2024

Inspection Number: 1173762

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okaloosa County**

License Number: 5603335

FAIRFIELD INN & SUITES DESTIN

License Type: Hotel

19001 EMERALD COAST PKWY, DESTIN 32541

Inspection Date: 02/21/2024

Inspection Number: 1172466

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: SHANKLIN, CYNTHIA

Violation Code

Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. # 130406. 4-13-23.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5801661

LA QUINTA INN

License Type: Motel

5825 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 02/22/2024

Inspection Number: 1230685

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOSTELNY, ROGER

Violation Code    Observation

Violation Citation

08-01-4            Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

FL13055, expired 2/15/24

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5803609

ORLANDO INTERNATIONAL DRIVE HOTEL NORTH

License Type: Motel

5859 AMERICAN WAY, ORLANDO 32819

Inspection Date: 02/20/2024

Inspection Number: 1233327

Inspection Type: Complaint Full

Inspection Disposition: Call Back - Complied

Inspector Name: KOSTELNY, ROGER

Violation Code    Observation

Violation Citation

04-01-4            - From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
In lobby    - From follow-up inspection 2024-01-31: **\*\*Time Extended\*\***    - From follow-up inspection 2024-02-20: **\*\*Time Extended\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5809119 EXTENDED STAYAMERICA #1613  
 License Type: Hotel 5620 MAJOR BLVD, ORLANDO 32819

Inspection Date: 02/22/2024 Inspection Number: 1172875 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: KOSTELNY, ROGER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FL094905 expired 8/9/21 **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FL094905 expired 8/9/21 **Repeat Violation** - From follow-up inspection 2024-02-23: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809156 HAMPTON INN ORLANDO CONVENTION CENTER  
 License Type: Hotel 8900 UNIVERSAL BLVD, ORLANDO 32819

Inspection Date: 02/23/2024 Inspection Number: 1172568 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: LUI, SUK HAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Both certificates 137772 and 137773 expired 12-20-2023	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Orange County**

License Number: 5809300

LA QUINTA BY WYNDAM ORLANDO I DRIVE CONVENTION CENTER

License Type: Hotel

8504 UNIVERSAL BLVD, ORLANDO 32819

Inspection Date: 02/23/2024

Inspection Number: 1173195

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LUI, SUK HAN

Violation Code

Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Certificate 131445 expired 6/3/23. **\*\*Repeat Violation\*\***

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

License Number: 5913659

MAGIC MOMENT RESORT AND KIDS CLUB

License Type: Motel

5200 W IRLO BRONSON HWY, KISSIMMEE 34746

Inspection Date: 02/19/2024

Inspection Number: 1233426

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SMITH JONES, SHANTASIA

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6014047

HYATT PLACE WEST PALM BEACH

License Type: Hotel

295 LAKEVIEW AVE, WEST PALM BEACH 33401

Inspection Date: 02/19/2024

Inspection Number: 1172845

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: AHLE, ROBERT

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **\*\*Repeat Violation\*\*** - From follow-up inspection 2024-02-19: **\*\*Time Extended\*\***

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Pinellas County**

License Number: 6207251 JEFFERSON APARTMENTS  
 License Type: Apartment 121 N JEFFERSON AVE, CLEARWATER 33755

Inspection Date: 02/17/2024 Inspection Number: 1574489 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-01-4	Exit sign missing. Wires hanging down from ceiling. Upstairs west side of building over stairs. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215812 RESIDENCE INN  
 License Type: Hotel 309 CORONADO DRIVE, CLEARWATER 33767

Inspection Date: 02/20/2024 Inspection Number: 1172911 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied  
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. <b>**Repeat Violation**</b> - From follow-up inspection 2024-02-20: <b>**Time Extended**</b>	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215813 SPRINGHILL SUITES  
 License Type: Hotel 309 CORONADO DR, CLEARWATER 33767

Inspection Date: 02/20/2024 Inspection Number: 1172913 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied  
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. <b>**Repeat Violation**</b> - From follow-up inspection 2024-02-20: <b>**Time Extended**</b>	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6900076

FLORIDA HOTEL

License Type: Hotel

500 S OAK AVE, SANFORD 327711880

Inspection Date: 02/19/2024

Inspection Number: 1172161

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: RUTLEDGE, REBECCA

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Memory/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2024-02-19:

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7406514 THE DAYTONA AUTOGRAPH COLLECTION  
 License Type: Hotel 1870 VICTORY CIR, DAYTONA BEACH 32114

Inspection Date: 02/21/2024 Inspection Number: 1173021 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. -supervisor and trouble lights on Per maintenance waiting on parts	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7400126 SILVER BEACH CLUB  
 License Type: Vacation Rental - Condo 1025 S ATLANTIC AVE, DAYTONA BCH 321184798

Inspection Date: 02/21/2024 Inspection Number: 1089618 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-01-4	Damaged/exposed electrical wire(s). For reporting purposes only. -from top panel of water heater, operator stated planned to replace unit	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406512 LOTUS INN & SUITES  
 License Type: Motel 505 S ATLANTIC AVE, ORMOND BEACH 32176

Inspection Date: 02/21/2024 Inspection Number: 1231412 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: RUTLEDGE, REBECCA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-04-4	Fire alarm control panel has no power. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.