

**Charlotte County**

License Number: 1801529

HOLIDAY INN EXPRESS AND SUITES PUNTA GORDA

License Type: Hotel

9075 MAC DR, PUNTA GORDA 33950

Inspection Date: 03/06/2024

Inspection Number: 1173962

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAYED, MOHAMMED

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only Jurisdiction No. 134468; 134477. Expiration Date: 01/19/2023.  
\*\*Repeat Violation\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Citrus County**

License Number: 1901157

WOODSPRING SUITES INVERNESS

License Type: Hotel

123 S SEMINOLE AVE, INVERNESS 34452

Inspection Date: 03/05/2024

Inspection Number: 1173444

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: DEMARCO, AMBER

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.  
Smoke detectors not sounding alarm when tested. Unable to test all detectors due to rooms being occupied.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2328208 MANDARIN ORIENTAL MIAMI  
 License Type: Hotel 500 BRICKELL KEY DR, MIAMI 33131

Inspection Date: 03/04/2024 Inspection Number: 1173994 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. <b>**Corrected On-Site**</b>	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329461 MINT HOUSE FLORIDA MUZE  
 License Type: Hotel 340 SE 3 ST FLR 21-22, MIAMI 33131

Inspection Date: 03/08/2024 Inspection Number: 1173422 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330248 MUZE AT MET  
 License Type: Apartment 340 SE 3 ST, MIAMI 33131

Inspection Date: 03/08/2024 Inspection Number: 1574320 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329505 THE ELSER HOTEL  
 License Type: Hotel 398 NE 5 ST, MIAMI 33132

Inspection Date: 03/07/2024 Inspection Number: 1173301 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CUDEMOS, VIRNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only. Observed 032187891, 032187892 and 042188088. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2306762 MOTEL 77 NEW 7  
 License Type: Motel 3021 SW 8 ST, MIAMI 33135

Inspection Date: 03/04/2024 Inspection Number: 1232119 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: GATO, RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Observed Hearing-impaired smoke detector strobe light not flashing when tested.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329207 SPRINGHILL SUITES BY MARRIOTT  
 License Type: Hotel 1311 NW 10TH AVE, MIAMI 33136

Inspection Date: 03/05/2024 Inspection Number: 1172959 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2330860 1135 NW 6  
 License Type: Apartment 1135 NW 6 ST, MIAMI 33136

Inspection Date: 03/06/2024 Inspection Number: 1573028 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-01-4	Observe electrical wire(s). Coming from apt 1 to meter room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304994 THE BLUE MOON HOTEL  
 License Type: Hotel 944 & 926 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 03/06/2024 Inspection Number: 1173897 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ASTROQUIZA, MIGUEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
03-04-4	Observed fire sprinkler head obstructed/covered at dumpster area. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310370 1685 JEFFERSON LLC  
 License Type: Apartment 1685 JEFFERSON AVE, MIAMI BEACH 33139

Inspection Date: 03/05/2024 Inspection Number: 1575935 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SWIGERT, RICHARD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed by apartment 1 and 10	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329049 HOTEL VICTOR  
 License Type: Hotel 1144 OCEAN DR, MIAMI BEACH 33139

Inspection Date: 03/07/2024 Inspection Number: 1173092 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ASTROQUIZA, MIGUEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. Observed jurisdiction 120078 and 120079 Expired 07.21.2022. For reporting purposes only. <b>**Repeat Violation**</b>	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329201 METROPOLE HOTEL  
 License Type: Hotel 635 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 03/07/2024 Inspection Number: 1172946 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ASTROQUIZA, MIGUEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. <b>**Repeat Violation**</b>	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329285 THE BALFOUR HOTEL MIAMI BEACH  
 License Type: Hotel 350 OCEAN DR, MIAMI BEACH 33139

Inspection Date: 03/05/2024 Inspection Number: 1175255 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ASTROQUIZA, MIGUEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329336 THE MERIDIAN HOTEL  
 License Type: Hotel 418 MERIDIAN AVE, MIAMI BEACH 33139

Inspection Date: 03/05/2024 Inspection Number: 1171799 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied  
 Inspector Name: ASTROQUIZA, MIGUEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Boilers water capacity at 200 gallons. - From follow-up inspection 2024-03-05: Observed no boiler certificate or insuran	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329297 MIAMI BEACH EDITION HOTEL  
 License Type: Hotel 2901 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 03/06/2024 Inspection Number: 1173560 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed at the panel located behind the front desk.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2305794 1236 MARSIELLE DRIVE  
 License Type: Apartment 1236 MARSEILLE DR, MIAMI BEACH 33141

Inspection Date: 03/08/2024 Inspection Number: 1580364 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GATO, RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-04-4	No portable fire extinguisher present on the premises. For reporting purposes only. Observed no fire extinguishers present on the premises.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329394 CASITA 76  
 License Type: Hotel 7610 HARDING AV, MIAMI BEACH 33141

Inspection Date: 03/08/2024 Inspection Number: 1172399 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied  
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed light in trouble inside housekeeping storage next to the laundry. - From follow-up inspection 2024-03-08: **Time Exten	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2310965 2164 NW 28 ST APTS  
 License Type: Apartment 2164 NW 28 ST, MIAMI 331425953

Inspection Date: 03/05/2024 Inspection Number: 1569327 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking devices for fire extinguisher located on the 1st and 2nd floor of apartment building. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329488 AC HOTEL MIAMI DADELAND  
 License Type: Hotel 7695 N KENDALL DR, MIAMI 33156

Inspection Date: 03/08/2024 Inspection Number: 1173300 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: LEIDECKER, EDILMA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed the boiler certificate is in process to be renewed. **Corrective Action Taken**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2311837 NORTH MIAMI BEACH GARDEN INN & SUITE  
 License Type: Motel 148 NW 167 ST, MIAMI 33169

Inspection Date: 03/06/2024 Inspection Number: 1233524 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SANDOVAL, GUELSYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Located in the office.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328337 INTERNATIONAL CLUB APARTMENTS  
 License Type: Apartment 1900 SW 122 AVE, MIAMI 33175

Inspection Date: 03/05/2024 Inspection Number: 1564566 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied  
 Inspector Name: RAMON, JESSICA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on building 1850 near unit 507. Observed no breaking device on building 1950	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2609173

STAYABLE SUITES JACKSONVILLE

License Type: Motel

812 DUNN AVE, JACKSONVILLE 32218

Inspection Date: 03/07/2024

Inspection Number: 1230806

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MERCER, THOMAS

Violation Code

Observation

Violation Citation

06-05-4

Door marked as an exit locked with a lock that would require special knowledge/tool to unlock. For reporting purposes only.  
Doors to outside walkway by rooms 301 and 302 have pad locks, only other exit is stairs. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Escambia County**

License Number: 2705829

HOME2/TRU BY HILTON PENSACOLA AIRPORT MEDICAL CENTER

License Type: Hotel

5109 BAYOU BLVD, PENSACOLA 32503

Inspection Date: 03/05/2024

Inspection Number: 1173742

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALBRITTON, GREGORY

Violation Code

Observation

Violation Citation

06-02-4

Door marked as an exit is blocked. For reporting purposes only.  
Exit door next to room 155 has caution tape and sign that displays "Sorry for the inconvenience, this door is out of order".

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3913614

EMBASSY SUITES HOTEL TAMPA-DOWNTOWN CONVENTION CENTER

License Type: Hotel

513 S FLORIDA AVE, TAMPA 33602

Inspection Date: 03/04/2024

Inspection Number: 1175239

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: AIELLO, ROCCI

Violation Code    Observation

Violation Citation

08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Operator states they will get information with documentation that they do not have Boilers, sent boiler information to operator	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	--

**Indian River County**

License Number: 4101331

COMFORT INN VERO BEACH

License Type: Hotel

9050 AMERICANA WAY, VERO BEACH 32966

Inspection Date: 03/04/2024

Inspection Number: 1174309

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHNEIDER, KIM

Violation Code

Observation

Violation Citation

04-01-4      Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Lee County**

License Number: 4602772

LA QUINTA INN AND SUITES

License Type: Hotel

20091 SUMMERLIN RD, FORT MYERS 33908

Inspection Date: 03/08/2024

Inspection Number: 1173454

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: SOMMERS, KARA

Violation Code

Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. 137013 expired 02/10/23, 137014 expired 02/10/23 For reporting purposes only. Educated operator on update boiler certifications. **\*\*Repeat Violation\*\***

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4605264

HOMEWOOD SUITES BY HILTON BONITA SPRINGS

License Type: Hotel

8901 HIGHLAND WOODS BLVD, BONITA SPRINGS 34135

Inspection Date: 03/07/2024

Inspection Number: 1171205

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SOMMERS, KARA

Violation Code

Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired-090304 10/23/2021, 090305 10/23/2021. Educated operator on updating boiler certificate. For reporting purposes only. **\*\*Repeat Violation\*\***

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Marion County**

License Number: 5200791

SUNBRITE APARTMENTS

License Type: Apartment

612 - 626 NE 26 AVE, OCALA 34470

Inspection Date: 03/04/2024

Inspection Number: 1564052

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FIGUEROA-ROBLES, TATIANA

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Extinguisher located at the laundry room area no breaking bar available.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okaloosa County**

License Number: 5603342

QUALITY INN OF CRESTVIEW FL

License Type: Hotel

151 CRACKER BARREL DR, CRESTVIEW 32536

Inspection Date: 03/07/2024

Inspection Number: 1172848

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BURROUGHS, RICHARD

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only:  
Room 125 - smoke detector missing.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Orange County**

License Number: 5807936 GRAND HOTEL ORLANDO  
 License Type: Hotel 7825 UNIVERSAL BLVD, ORLANDO 32819

Inspection Date: 03/06/2024 Inspection Number: 1175214 Inspection Type: Complaint Partial Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: KOSTELNY, ROGER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In between room 243 and 242 on breezeway Operator stated coming out this week to check all extinguishers	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810198 HILTON GARDEN INN ORLANDO SEA WORLD  
 License Type: Hotel 6850 WESTWOOD BLVD, ORLANDO 32821

Inspection Date: 03/04/2024 Inspection Number: 1174880 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: WHITE, EILEEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Working to get carbon dioxide devices installed.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5809180 HILTON GARDEN INN ORLANDO AIRP  
 License Type: Hotel 7300 AUGUSTA NATIONAL DR, ORLANDO 32822

Inspection Date: 03/06/2024 Inspection Number: 1174176 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: WHITE, EILEEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5811143

FOUR SEASONS RESORT ORLANDO

License Type: Hotel

10100 DREAM TREE BLVD, ORLANDO 32836

Inspection Date: 03/05/2024

Inspection Number: 1173240

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PICHARDO, RENEE

Violation Code

Observation

Violation Citation

08-04-4 Boiler certificate not posted in the boiler room. For reporting purposes only. 3 expired certificates and 2 missing certificates posted

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

License Number: 5900204

RAMADA PLAZA HOTEL & INN GATEWAY

License Type: Motel

7470 HWY 192 W, KISSIMMEE 34747

Inspection Date: 03/06/2024

Inspection Number: 1233506

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: QUIJANO, LAUREN

Violation Code    Observation

Violation Citation

08-01-4            Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Operator has ongoing communication with Fire Marshall and awaiting their approvals.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6007675

HILTON SUITE HOTEL

License Type: Hotel

7920 GLADES RD, BOCA RATON 33434

Inspection Date: 03/04/2024

Inspection Number: 1173632

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: GONZALEZ, DENNIS

Violation Code

Observation

Violation Citation

08-06-4

Combustibles stored in boiler room. For reporting purposes only. Box of furniture in boiler, blocking boiler

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Sarasota County**

License Number: 6804756 SIESTA KEY PALMS HOTEL  
 License Type: Hotel 1800 STICKNEY POINT RD, SARASOTA 34231

Inspection Date: 03/05/2024 Inspection Number: 1173744 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: RODARTE, ERIC

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed a missing hammer for the fire extinguisher box in front of unit 21.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6800192 BAYMONT INN & SUITES  
 License Type: Motel 1425 S TAMIAMI TRL, SARASOTA 34239

Inspection Date: 03/06/2024 Inspection Number: 3420863 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SURWILLO, JACQUELINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Fire panel shows trouble. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6800625 NOKOMIS GULF COAST INN  
 License Type: Motel 119 N TAMIAMI TRAIL, NOKOMIS 34275

Inspection Date: 03/05/2024 Inspection Number: 1233129 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied  
 Inspector Name: RODARTE, ERIC

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher between units 102 and 103. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2024-03-05: **Time Exte	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing hammers for fire extinguisher box between rooms 102 and 103. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6903996

MAA TWIN LAKES

License Type: Apartment

11500 MYRTLEWOOD DR, SANFORD 32771

Inspection Date: 03/06/2024

Inspection Number: 1580431

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Complied

Inspector Name: JENKINS, ELAINE

Violation Code    Observation

Violation Citation

04-01-4            - From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
-building 5    - From follow-up inspection 2024-03-06: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6903990

EXTENDED STAY AMERICA SELECT SUITES 8016

License Type: Hotel

2727 S ORLANDO DR, SANFORD 32773

Inspection Date: 03/07/2024

Inspection Number: 1170437

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation Code    Observation

Violation Citation

04-01-4            Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7400503	BAYMONT INN & SUITES		
License Type: Motel	2725 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32114		
Inspection Date: 03/06/2024	Inspection Number: 1233485	Inspection Type: Complaint Full	Inspection Disposition: Warning Issued
Inspector Name: BRANNER, LISELOTTE			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
06-02-4	Door marked as an exit is blocked. For reporting purposes only. -building 3 first level establishment placed a door in the middle of hallway and at the beginning of the hallway by room 138. Doors has a hasp ,currently not locked.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7401109	OCEAN EDGE AT DAYTONA		
License Type: Motel	735 N ATLANTIC AVE, DAYTONA BEACH 32118		
Inspection Date: 03/06/2024	Inspection Number: 1231721	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: WOOD, JUSTIN			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
05-02-5	Hearing-impaired smoke detector is not functioning when attempted to be tested. For reporting purposes only.  -BRK brand hearing impaired smoke detector was disabled **Warning**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406508	BEACHSIDE HOTEL		
License Type: Motel	3309 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118		
Inspection Date: 03/06/2024	Inspection Number: 1231967	Inspection Type: Routine - Lodging	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: WOOD, JUSTIN			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Volusia County**

License Number: 7406519

HAWAIIAN INN BEACH RESORT

License Type: Hotel

2301 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 03/09/2024

Inspection Number: 1174062

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: WOOD, JUSTIN

Violation Code      Observation

Violation Citation

08-03-4      No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-08-4      Vent stack for gas water heater inside boiler room in disrepair. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406523

MAX BEACH RESORT

License Type: Hotel

1901 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 03/09/2024

Inspection Number: 1173429

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code      Observation

Violation Citation

08-03-4      No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.  
  
-operator has ongoing work coordinated with boiler inspector

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7406495

HOLIDAY INN DAYTONA BEACH LPGA

License Type: Hotel

137 AUTOMALL CIR, DAYTONA BEACH 32124

Inspection Date: 03/05/2024

Inspection Number: 1174072

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: COREY, DEREK

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.