

Bay County

License Number: 1300286

SANDPIPER BEACON BEACH RESORT

License Type: Motel

17403 FRONT BEACH RD, PANAMA CITY BEACH 32413

Inspection Date: 03/11/2024

Inspection Number: 1230841

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HAASE, TINA

Violation Code

Observation

Violation Citation

03-05-4 Fire sprinkler head painted. For reporting purposes only. Observed painted sprinkler heads on floors 5 and 6. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1503598

AMERICAS BEST VALUE INN & SUITES

License Type: Motel

4431 W NEW HAVEN AVE, MELBOURNE 32904

Inspection Date: 03/11/2024

Inspection Number: 1233513

Inspection Type: Complaint Partial

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MITTEN, JAMES

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Extinguisher in front of room 139
Operator explained a guest discharged it over the weekend

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621565 PROBIZ ESTATE INVESTMENT MIR2, LLC
 License Type: Apartment 7221 VENETIAN STREET, MIRAMAR 33023

Inspection Date: 03/13/2024 Inspection Number: 1563271 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PIERRE, ENOSE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher next to unit 4 indicates that it has been used.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1600334 THE RIVERSIDE HOTEL
 License Type: Hotel 620 E LAS OLAS BLVD, FORT LAUDERDALE 33301

Inspection Date: 03/12/2024 Inspection Number: 1175267 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620932 FOUR SEASONS HOTEL AND RESIDENCES FORT LAUDERDALE
 License Type: Hotel 525 N FT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304

Inspection Date: 03/11/2024 Inspection Number: 1172068 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BRANN, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1619051 HOMETOWNE STUDIOS - FORT LAUDERDALE 3512
 License Type: Hotel 3031 W COMMERCIAL BLVD, FORT LAUDERDALE 33309

Inspection Date: 03/12/2024 Inspection Number: 1175282 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RICCIO, SUSAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light illuminated.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1612422 LAQUINTA INN & SUITES
 License Type: Motel 351 W HILLSBORO BLVD, DEERFIELD BEACH 33441

Inspection Date: 03/11/2024 Inspection Number: 1233543 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: JOHNSON, CHRISTINA NOEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-03-4	Smoke detector in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Room 327 and Room 201.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300197 POMELO GROVE INVESTMENTS LLC
 License Type: Apartment 68 NW 17 CT, MIAMI 33125

Inspection Date: 03/11/2024 Inspection Number: 1562183 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: PONCE, JIMMIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguisher in box with no break in device next to unit 2. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2307611 MIAMI AIRPORT MARRIOTT- FULL SERVICE
 License Type: Hotel 1201 NW 42 AVE, MIAMI 331262656

Inspection Date: 03/13/2024 Inspection Number: 1173316 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FICHTER, GARRICK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 093828 expired in 2023. Verified on fire website	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2313981 COURTYARD BY MARRIOTT
 License Type: Motel 200 SE 2 AVE, MIAMI 33131

Inspection Date: 03/14/2024 Inspection Number: 1233498 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Corrected On-Site**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330492

PANORAMA TOWER

License Type: Apartment

1100 BRICKELL BAY DR, MIAMI 33131

Inspection Date: 03/12/2024

Inspection Number: 1564793

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329308

GATES HOTEL

License Type: Hotel

2360 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 03/14/2024

Inspection Number: 1173965

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SWIGERT, RICHARD

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Laundry room 138177, expired on 06-01-22, Observed two boilers on the roof IN501-1134 and IN 501-1145 newly installed have not been inspected.
**Repeat Viola

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329320

NAUTILUS SONESTA MIAMI BEACH

License Type: Hotel

1825 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 03/13/2024

Inspection Number: 1174039

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SWIGERT, RICHARD

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329478	THE GABRIEL SOUTH BEACH	
License Type: Hotel	620-650 OCEAN DRIVE, MIAMI BEACH	33139
Inspection Date: 03/11/2024	Inspection Number: 1174311	Inspection Type: Routine - Lodging
Inspector Name: ASTROQUIZA, MIGUEL		Inspection Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329428	VENEZIA AT MINE	
License Type: Hotel	3865 INDIAN CREEK DR, MIAMI BEACH	33140
Inspection Date: 03/12/2024	Inspection Number: 1174508	Inspection Type: Routine - Lodging
Inspector Name: UNZAGA, MILADYS		Inspection Disposition: Call Back - Complied

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed light in trouble in panel located behind front desk. **Repeat Violation** - From follow-up inspection 2024-03-12: **T	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2322921	LA QUINTA BY WYNDHAM AIRPORT EAST	
License Type: Hotel	3501 NW 42 AVE, MIAMI	33142
Inspection Date: 03/14/2024	Inspection Number: 1174320	Inspection Type: Routine - Lodging
Inspector Name: COREY, DEREK		Inspection Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only. -boiler #135427 certificate not posted, operator posted **Corrected On-Site**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329237 ELEMENT MIAMI INTERNATIONAL AIRPORT
 License Type: Hotel 3525 NW 25 ST, MIAMI 33142

Inspection Date: 03/11/2024 Inspection Number: 1170657 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: COREY, DEREK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Both Expired on 09/09/23. - From follow-up inspection 2024-03-11: Operator states they have had Travelers insurance inspector	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. -Operator states they have had Travelers insurance inspector on site to inspect boilers, operator awaiting updated certificate from state Fire Marshal. **Rep	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329315 HYATT PLACE MIAMI AIRPORT EAST
 License Type: Hotel 3549 NW LEJEUNE RD, MIAMI SPRINGS 33142

Inspection Date: 03/15/2024 Inspection Number: 1173931 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: COREY, DEREK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. -operator states repairs have been requested **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2305583

CORAL VIEW MANOR

License Type: Apartment

5712 SW 19 ST, MIAMI 33155

Inspection Date: 03/14/2024

Inspection Number: 1559954

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation Code

Observation

Violation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed near unit 204.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2324370

THE STRATFORD APARTMENTS

License Type: Apartment

9051 SW 122 AVE, MIAMI 33186

Inspection Date: 03/14/2024

Inspection Number: 1568695

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back - Extension given, pending

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

04-01-4 - From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed by building 9001. - From follow-up inspection 2024-03-14: Observed trouble lights illuminated, building 9001 **Time Ext

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2608615 MOTEL 6 JACKSONVILLE ORANGE PARK
 License Type: Motel 6107 YOUNGERMAN CIR, JACKSONVILLE 32244

Inspection Date: 03/11/2024 Inspection Number: 1233525 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher by establishment laundry area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Two extinguishers missing from location - one by room 151 and one by guest laundry.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certification expired 09/10/2022. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2609384 COMFORT SUITES
 License Type: Hotel 8277 WESTERN WAY, JACKSONVILLE 32256

Inspection Date: 03/15/2024 Inspection Number: 1173090 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BADDING, MELANIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble light illuminated on Fire Panel during inspection person in charge states working with Pye Baker to find solution as repair has been made but light is s	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3912167

OAK CHASE APARTMENTS I

License Type: Apartment

12535 TINSLEY CIR, TAMPA 33612

Inspection Date: 03/12/2024

Inspection Number: 1580347

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: DUNN, MIKAYLA

Violation Code

Observation

Violation Citation

01-03-4 - From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
In laundry area - From follow-up inspection 2024-03-12: Fire extinguisher verifie

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-04-4 - From initial inspection : Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Exposed wiring on lamp near unit 131 12523
Electrical panel missing at building 12503 - From follow-up inspection
2024-03-12: **Time Exten

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4602772

LA QUINTA INN AND SUITES

License Type: Hotel

20091 SUMMERLIN RD, FORT MYERS 33908

Inspection Date: 03/12/2024

Inspection Number: 1173454

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: SOMMERS, KARA

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. 137013 expired 02/10/23, 137014 expired 02/10/23 For reporting purposes only. Educated operator on update boiler certifications. **Repeat Violation** - Fro

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Levy County

License Number: 4800478

DAYS INN

License Type: Motel

809 NW 21 AVE, CHIEFLAND 32626

Inspection Date: 03/11/2024

Inspection Number: 1233545

Inspection Type: Complaint Partial

Inspection Disposition: Warning Issued

Inspector Name: BERRY, JOHNNY

Violation Code

Observation

Violation Citation

04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Smoke alarm missing from inside room 215. **Warning**	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Electrical outlet pulled out from wall behind night stand inside room 207. **Warning**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5202485

THE RIDING ACADEMY

License Type: Hotel

1615 NW 81 TERR RD, OCALA 34482

Inspection Date: 03/14/2024

Inspection Number: 1175020

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: TORRES, WILLIAM

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
Establishment had inspection down two days ago and are waiting for the boiler certificate to be issued

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5403198

PLAYA LARGO RESORT & SPA

License Type: Hotel

97450 OVERSEAS HWY, KEY LARGO 33037

Inspection Date: 03/12/2024

Inspection Number: 1173033

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOMEZ-SANCHEZ, NELLY

Violation Code

Observation

Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5804711 HOME INN & SUITES
 License Type: Motel 1440 W ORANGE BLOSSOM TRAIL, APOPKA 32712

Inspection Date: 03/12/2024 Inspection Number: 1231144 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MONTGOMERY, DOREEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
05-02-5	Hearing-impaired smoke detector is not functioning when tested, smoke detector does not flash when tested, For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5805056 RED ROOF PLUS ORLANDO
 License Type: Hotel 8342 JAMAICAN CT, ORLANDO 32819

Inspection Date: 03/12/2024 Inspection Number: 1175275 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BACHOO, SAVITRI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificates or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5810223 LAKE BUENA VISTA RESIDENCE INN
 License Type: Hotel 11450 MARBELLA PALMS CT, ORLANDO 32836

Inspection Date: 03/11/2024 Inspection Number: 1170435 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificates expired 3/3/2024 Spoke to Engineering staff.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6006521

HILTON PALM BEACH AIRPORT

License Type: Hotel

150 AUSTRALIAN AVE, WEST PALM BEACH 33406

Inspection Date: 03/12/2024

Inspection Number: 1175280

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: FRANCE, GASTON

Violation Code

Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

132977- expired 9/24/22, 125233- expired 9/24/22.

Repeat Violation

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6202516

BAY POINTE TOWER APARTMENTS

License Type: Apartment

880 OLEANDER WAY S, SOUTH PASADENA 33707

Inspection Date: 03/15/2024

Inspection Number: 1581056

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: HOWEY, JANINE

Violation CodeObservationViolation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Expired 10-3-2021 **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6201091

BETTY LANE APARTMENTS

License Type: Apartment

311 S BETTY LANE, CLEARWATER 33756

Inspection Date: 03/16/2024

Inspection Number: 1564886

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PEARCE, LAURA

Violation CodeObservationViolation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher in laundry room - missing tool . For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6216319

1132 SUNSHINE APARTMENTS LLC

License Type: Apartment

1132 AUBURN ST, CLEARWATER 33756

Inspection Date: 03/13/2024

Inspection Number: 1581023

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PEARCE, LAURA

Violation CodeObservationViolation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel in laundry room for zone 1 . For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6301099

STAY PLUS INN

License Type: Motel

33224 HWY 27 S, HAINES CITY 33844

Inspection Date: 03/15/2024

Inspection Number: 1231589

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: BUCKNER, ELLIOT

Violation Code

Observation

Violation Citation

04-03-4

- From initial inspection : Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Room 159
Has 2 smoke alarm one is in disrepair. - From follow-up inspection 2024-03-15:
Room is rented at time of

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6800602

CASEY KEY RESORTS - MAINLAND

License Type: Motel

1660 S TAMIAMI TRAIL, OSPREY 34229

Inspection Date: 03/11/2024

Inspection Number: 1231364

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: RODARTE, ERIC

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge between rooms 138 and 140. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-06-4

Fire alarm emitting an audible alarm on the 2nd of the Parkside lobby. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6801207

A BEACH RETREAT

License Type: Motel

108 CASEY KEY RD, NOKOMIS 34275

Inspection Date: 03/11/2024

Inspection Number: 1232233

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: RODARTE, ERIC

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge near the dock of the bayside property. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400715 GRANDPRIXMOTEL
 License Type: Motel 2015 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 03/15/2024 Inspection Number: 1231845 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. -unit 44	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-01-4	Damaged electrical wire(s). For reporting purposes only. -in front of unit 35, person in charge stated not known what its purpose is.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406519 HAWAIIAN INN BEACH RESORT
 License Type: Hotel 2301 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 03/09/2024 Inspection Number: 1174062 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: WOOD, JUSTIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-08-4	Vent stack for gas water heater inside boiler room in disrepair. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406523

MAX BEACH RESORT

License Type: Hotel

1901 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 03/09/2024

Inspection Number: 1173429

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

-operator has ongoing work coordinated with boiler inspector

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7405218

EXTENDED STAY OF ORMOND

License Type: Motel

1608 N US HWY 1, ORMOND BEACH 32174

Inspection Date: 03/12/2024

Inspection Number: 1233517

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: RUTLEDGE, REBECCA

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.
-smoke detector missing in rooms 171 and 261.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406519

BAYMONT INN & SUITES

License Type: Motel

175 INTERCHANGE BLVD, ORMOND BEACH 32174

Inspection Date: 03/12/2024

Inspection Number: 1233511

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation CodeObservationViolation Citation

07-04-4

Electrical outlet missing cover in second floor hallway. For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406520

EXTENDED STAY AMERICA #9512

License Type: Hotel

275 INTERCHANGE BLVD, ORMOND BEACH 32174

Inspection Date: 03/14/2024

Inspection Number: 1173409

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation Code Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-03-4 No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Establishment has two boilers. Establishment has a boiler certificate for one of the boilers which expired 02/25/2023. No certificate provided for the o

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.