

Observation

Baker County

License Number: 1200123

TRAVELODGE

License Type: Motel

1651 S 6TH STREET, MACCLENNY 32063

Inspection Date: 04/01/2024

Inspection Number: 1232139

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PERKINS, MARC

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher by unit 102 and 101 in the recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

Brevard County

License Number: 1501161

SPACE COAST HOTEL

License Type: Motel

3500 CHENEY HWY, TITUSVILLE 32780

Inspection Date: 04/05/2024

Inspection Number: 1233639

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: FRANZ, LINDA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel.
For reporting purposes only. Titusville fire posted out of order.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

Broward County

License Number: 1620877

CHATEAU MAR GOLF RESORT

License Type: Hotel

3501 INVERRARY BLVD, LAUDERHILL 33319

Inspection Date: 04/01/2024

Inspection Number: 1174234

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: LINDEN, TAD

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired.
For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

Collier County

License Number: 2102299

BEST WESTERN HOTEL & SUITES

License Type: Motel

6400 DUDLEY DR, NAPLES 34105

Inspection Date: 04/05/2024

Inspection Number: 1231693

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MEADE, ARTHUR

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler Certificate Expired 12-13-2021 133059 and 12-13-2021 133060

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

Dade County

License Number: 2300323 LAS BRISAS APARTMENTS LLC
 License Type: Apartment 47 & 55 W 7 ST, HIALEAH 33010

Inspection Date: 04/02/2024 Inspection Number: 1579010 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-05-4	Portable fire alarm obstructed/not accessible. For reporting purposes only. Observed all fire alarm boxes around building missing handle to break glass.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2317292 HOLIDAY INN
 License Type: Hotel 7707 NW 103 ST, HIALEAH GARDENS 33016

Inspection Date: 04/05/2024 Inspection Number: 1175375 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ELDER, AUDREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed no boiler certificate for one of two boilers. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

Dade County

License Number: 2330654 NEW POMELO
 License Type: Apartment 19279 NW 27 AVE, MIAMI GARDENS 33056-2562

Inspection Date: 04/01/2024 Inspection Number: 1572933 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: SANDOVAL, GUELSYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher in the recharge zone in floor 1 by elevator.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
06-04-4	No door knob/opening device on marked exit door. For reporting purposes only. Observed exit door not able to open at building 2 by the south side stairway.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329896 MELODY TOWER
 License Type: Apartment 245 NE 14 ST MANAGEMENT OFFICE, MIAMI 33132

Inspection Date: 04/02/2024 Inspection Number: 1570107 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CUDEMOS, VIRNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2305333 AXEL BEACH
 License Type: Hotel 1500 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 04/03/2024 Inspection Number: 1174685 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SWIGERT, RICHARD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

Dade County

License Number: 2306162 THE LIBAZI
 License Type: Apartment 845 - 849 MICHIGAN AVE, MIAMI BEACH 33139

Inspection Date: 04/01/2024 Inspection Number: 1574077 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ASTROQUIZA, MIGUEL

Violation Code Observation Violation Citation

01-02-4 Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher in the recharge zone near unit 12 at building 845. 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329312 CLAREMONT HOTEL
 License Type: Hotel 1700 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 04/01/2024 Inspection Number: 1174346 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SWIGERT, RICHARD

Violation Code Observation Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329486 ESMÈ MIAMI BEACH
 License Type: Hotel 1434-1438 WASHINGTON AVE, MIAMI BEACH 33139

Inspection Date: 04/02/2024 Inspection Number: 1173821 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SWIGERT, RICHARD

Violation Code Observation Violation Citation

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation** 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2304345 HOLIDAY INN MIAMI BEACH OCEANFRONT
 License Type: Hotel 4333 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 04/01/2024 Inspection Number: 1174610 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RAMON, JESSICA

Violation Code Observation Violation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

Dade County

License Number: 2300525 D`OR APTS
 License Type: Apartment 7301 HARDING AVE, MIAMI BEACH 331412724

Inspection Date: 04/05/2024 Inspection Number: 1578472 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GATO, RANDY

Violation Code Observation Violation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguisher locked in a box with no means of access near unit 3. 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329188 TRUMP INTL BEACH RESORT
 License Type: Hotel 18001 COLLINS AVE, SUNNY ISLES BEACH 33160

Inspection Date: 04/02/2024 Inspection Number: 1171304 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Complied
 Inspector Name: TAYLOR, JOHN

Violation Code Observation Violation Citation

08-01-4 - From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. As of 12/24/20. ****Warning**** - From follow-up inspection 2024-04-02: Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. As of 12/24/20. ****Warning** **Time Extended**** 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4 Boiler certificate or insurance inspector's boiler report expired. As of 12/24/20. For reporting purposes only. ****Repeat Violation*** 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

Dade County

License Number: 2331130 THE CONTEMPORARY
 License Type: Apartment 9105 SW 24TH ST, MIAMI 33165

Inspection Date: 04/03/2024 Inspection Number: 1581216 Inspection Type: Lodging-Licensing Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ELDER, AUDREY Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed two 499,000 BTU Boilers with no certification. As per office manager, Deputy boiler inspector visited on 4-2-24 to assess boiler for certification	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328943 BEST WESTERN PLUS MIAMI DORAL
 License Type: Motel 3875 NW 107 AVE, MIAMI 33178

Inspection Date: 04/05/2024 Inspection Number: 1231707 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

Duval County

License Number: 2612235

RED ROOF INN #10251

License Type: Motel

6969 LENOIR AVE E, JACKSONVILLE 32216

Inspection Date: 04/01/2024

Inspection Number: 1231769

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VILBRUN, JOSUE

Violation Code Observation

Violation Citation

08-03-4 No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
 Boiler site shows 6 boilers with 4 removed. Other two below are active & has no certificates or expiration date but only jurisdiction number (Jurisdiction # 139831 & no expiration date / Jurisdiction # 139832 & no expiration date). The 2 certificates posted in boiler room are for the ones removed as per boiler site which are expired.
****Repeat Violation** **Repeat Violation****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612319

DOUBLETREE BY HILTON JACKSONVILLE AIRPORT

License Type: Hotel

2101 DIXIE CLIPPER RD, JACKSONVILLE 32218

Inspection Date: 04/01/2024

Inspection Number: 1173271

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MERCER, THOMAS

Violation Code Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
 Boiler certificates expired 3/17/2024. Operator stated they are waiting on new certificates.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

Hillsborough County

License Number: 3905879

WESTIN HARBOUR ISLAND

License Type: Hotel

725 S HARBOUR ISLAND BLVD, TAMPA 33602

Inspection Date: 04/03/2024

Inspection Number: 1174686

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: AIELLO, ROCCI

Violation Code Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired.
For reporting purposes only. 2022

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

Lee County

License Number: 4601147

THEE BOARDWALK

License Type: Apartment

4637 DELEON ST, FORT MYERS 33907

Inspection Date: 04/04/2024

Inspection Number: 1581291

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: YURDAKUL, AYKAN

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Fire extinguisher at laundry room not accessible.
Fire extinguisher front of unit 163 not accessible.
Fire extinguisher front of unit 120 not accessible.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5602925

SHANGRA WOODS APTS

License Type: Apartment

940 ASHLEY LN, FT WALTON BCH 325476798

Inspection Date: 03/30/2024

Inspection Number: 1573437

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BURROUGHS, RICHARD

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only:

Building 3, Apartment 13 - fire extinguisher located outside of door and has been discharged.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

Okeechobee County

License Number: 5700001

HAMPTON INN OBEFL

License Type: Hotel

1200 SR 70 E, OKEECHOBEE 34972

Inspection Date: 04/05/2024

Inspection Number: 1174028

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JACKS, ALBERT

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel.
For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

Orange County

License Number: 5801635 VACATION LODGE
License Type: Motel 720 S ORANGE BLOSSOM TRL, ORLANDO 32805-3144

Inspection Date: 04/04/2024 Inspection Number: 1233633 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
Inspector Name: ANDINO, CATHERINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler 1#122391 2/23/2018 Boiler2 # 121247 2/23/18	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5805841 MI CASA HOTELS
License Type: Motel 9350 TURKEY LAKE RD, ORLANDO 32819

Inspection Date: 04/05/2024 Inspection Number: 1233575 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied
Inspector Name: LUI, SUK HAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only./FL058775, 058776/both expired 2/19/2024. - From follow-up inspection 2024-04-05: **Time Extended**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811135 AVANTI RESORT
License Type: Hotel 8738 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 04/03/2024 Inspection Number: 1174012 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LUI, SUK HAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only./FL056941, expired 1/8/2023.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

Orange County

License Number: 5803843

CLARION INN INTERNATIONAL DRIVE

License Type: Hotel

8444 INTERNATIONAL DR, ORLANDO 32819-9329

Inspection Date: 04/02/2024

Inspection Number: 1175355

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: LUI, SUK HAN

Violation Code

Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired.
For reporting purposes only.
FL134289, 134288/both expired 8/3/2023.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5804928

SHERATON SUITES ORLANDO AIRPORT

License Type: Hotel

7550 AUGUSTA NATIONAL DR, ORLANDO 328225020

Inspection Date: 04/04/2024

Inspection Number: 1174684

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITE, EILEEN

Violation Code

Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired.
For reporting purposes only. ****Repeat Violation****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-06-4 Combustibles stored in boiler room. For reporting purposes only
Cardboard boxes

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

Orange County

License Number: 5811154

SPRINGHILL SUITES ORLANDO FC/WESTERN ENTRANCE

License Type: Hotel

13279 FLAMINGO CROSSINGS BLVD, BAY LAKE 34787

Inspection Date: 04/04/2024

Inspection Number: 1174322

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BACHOO, SAVITRI

Violation Code Observation

Violation Citation

08-01-4	Boiler certificates or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	--

Observation

Osceola County

License Number: 5900225

SERALAGO HOTEL AND SUITES MAINGATE EAST

License Type: Hotel

5678 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 04/04/2024

Inspection Number: 1175365

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PASIECKI, VICTORIA

Violation Code Observation

Violation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside room 116	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-03-4	Scorch marks around an electrical outlet. For reporting purpose only. Room 221 at sink	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Trying to contact states fire Marshall.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

Osceola County

License Number: 5900576

RED LION HOTEL LAKE BUENA VISTA SOUTH

License Type: Hotel

5150 W IRLO BRONSON HWY, KISSIMMEE 34746

Inspection Date: 04/03/2024

Inspection Number: 1173743

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired.
For reporting purposes only.

-operator stated ongoing work with fire insurance over
recertification of boilers on site.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

Palm Beach County

License Number: 6014223

PSR HOMES 2 LLC

License Type: Apartment

925 SOUTH K STREET, LAKE WORTH 33460

Inspection Date: 04/02/2024

Inspection Number: 1578986

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: SINGH, GAJENDRA

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Between Apartment 15 and 16

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

Seminole County

License Number: 6903999

EXTENDED STAY AMERICA #9513

License Type: Hotel

1437 RINEHART RD, SANFORD 32771

Inspection Date: 04/03/2024

Inspection Number: 1174273

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: JENKINS, ELAINE

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

-boilers have been inspected and have stickers on them showing inspection date 2/23/23 with an expiration date of 2/21/25. Per operator, there has been a problem with invoicing/billing. Until the problem is resolved, the actual certificates will not be issued Equipment ID#F015236-136005 and -136006 **Repeat Violator

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

